



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

COMMONWEALTH EDISON COMPANY

DOCKET NO. 50-374

LASALLE COUNTY STATION, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 52
License No. NPF-18


1. The Nuclear Regulatory Commission (the Commission or the NRC) has found that:
 - A. The application for amendment filed by the Commonwealth Edison Company (the licensee), dated December 2, 1988, and supplemented on January 11, 1989, and May 17, 1989, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the enclosure to this license amendment and paragraph 2.C.(2) of the Facility Operating License No. NPF-18 is hereby amended to read as follows:

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 52, and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This amendment is effective upon date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Paul C. Shemanski, Acting Director
Project Directorate III-2
Division of Reactor Projects - III,
IV, V and Special Projects
Office of Nuclear Reactor Regulation

Enclosure:
Changes to the Technical
Specifications

Date of Issuance: October 25, 1989

ENCLOSURE TO LICENSE AMENDMENT NO. 52

FACILITY OPERATING LICENSE NO. NPF-18

DOCKET NO. 50-374

Replace the following pages of the Appendix "A" Technical Specifications with the enclosed pages. The revised pages are identified by amendment number and contain a vertical line indicating the area of change.

REMOVE

3/4 8-24

3/4 8-25

INSERT

3/4 8-24

3/4 8-25

TABLE 3.8.3.2-1

PRIMARY CONTAINMENT PENETRATION CONDUCTOR
OVERCURRENT PROTECTIVE DEVICES

<u>DEVICE NUMBER AND LOCATION</u>	<u>SYSTEM/COMPONENT POWERED</u>
a. <u>6.9 kV Circuit Breakers</u>	
1. Swgr. 251 (Bkr. 3A)	RR Pump 2A Primary - fast speed
2. Swgr. 252 (Bkr. 3B)	RR Pump 2B Primary - fast speed
3. Swgr. 251-1 (Brk. 2A)	RR Pump 2A, Primary - low speed
4. Swgr. 252-1 (Brk. 2B)	RR Pump 2B, Primary - low speed
5. Swgr. 251-1 (Brk. 4A)	RR Pump 2A, Backup - fast speed
6. Swgr. 252-1 (Brk. 4B)	RR Pump 2B Backup - fast speed
b. <u>4.16 kV Circuit Breakers</u>	
1. Swgr. 241Y (Brk. 1A)	RR Pump 2A Backup - low speed
2. Swgr. 242Y (Brk. 1B)	RR Pump 2B Backup - low speed
c. <u>480 VAC Circuit Breakers</u>	
1. Swgr. 236Y (Compt. 400A)	VP/Pri. Cont. Vent Supply Fan 2B
2. Swgr. 235Y (Compt. 202C)	VP/Pri. Cont. Vent Supply Fan 2A
d. <u>480 VAC (Molded Case) Circuit Breakers</u>	
1. Backup breakers are located in the back of the respective MCC.	
a) MCC 236Y-2 (Compt. C4)	RR/MOV 2B33-F067B
b) MCC 236Y-2 (Compt. A3)	RR/MOV 2B33-F023B
c) MCC 234X-1 (Compt. B3)	NB/MOV1 2B21-F001

TABLE 3.8.3.2-1 (Continued)

<u>DEVICE NUMBER AND LOCATION</u>	<u>SYSTEM/COMPONENT POWERED</u>
d) MCC 234X-1 (Compt. B4)	NB/MOV 2B21-F002
e) MCC 236Y-1 (Compt. B2 (Normal))	RH/MOV 2E12-F009
f) MCC 236Y-2 (Compt. E4)	RI/MOV 2E51-F063
g) MCC 235Y-1 (Compt. A1)	RR/MOV 2B33-F023A
h) MCC 235Y-1 (Compt. A4)	RR/MOV 2B33-F067A
i) MCC 233-1 (Compt. C2)	RT/MOV 2G33-F102
j) MCC-233-1 (Compt. E1)	NB/MOV 2B21-F005
k) MCC-236Y-2 (Compt. B1)	NB/MOV 2B21-F016
l) MCC 236Y-2 (Compt. E1)	RH/MOV 2E12-F099A
m) MCC 236Y-1 (Compt. E4)	RT/MOV 2G33-F001
n) MCC 236Y-2 (Compt. A5)	WR/MOV 2WR180
o) MCC 236Y-2 (Compt. D6)	RH/MOV 2E12-F099B
p) MCC 236Y-1 (Compt. H5)	VP/MOV 2VP113B
q) MCC 236Y-1 (Compt. H4)	VP/MOV 2VP114A
r) MCC 236Y-1 (Compt. H3)	VP/MOV 2VP113A
s) MCC 236Y-1 (Compt. H6)	VP/MOV 2VP114B
t) MCC 236Y-2 (Compt. A4)	WR/MOV 2WR179
u) MCC 235Y-1 (Compt. D3)	RT/MOV 2G33-F101
v) MCC 235Y-1 (Compt. D4)	RT/MOV 2G33-F100
w) MCC 233-1 (Compt. C3)	RT/MOV 2G33-F106
x) MCC 236Y-2 (Compt. D5)	RI/MOV 2E51-F076
y) MCC 235X-1 (Compt. C2/C3) (Emerg)	RH/MOV 2E12-F009
2. Backup breakers are located in the front of the respective MCC.	
a) MCC 235X-2 (Compt. AA4)	VP/Pri. Cont. Vent Supply Fan 2A Backup
b) MCC 236X-2 (Compt. AA4)	VP/Pri. Cont. Vent Supply Fan 2B Backup