



**Commonwealth Edison**  
 Zion Generating Station  
 Shiloh Blvd. & Lake Michigan  
 Zion, Illinois 60099  
 Telephone 312/746-2084

Dco

October 26, 1989

Mr. A. Bert Davis  
 Regional Administrator  
 Office of Inspection and Enforcement  
 Region III  
 U. S. Nuclear Regulatory Commission  
 Glen Ellyn, Illinois 60137

Dear Mr. Davis:

In accordance with Zion Station Technical Specification 4.3.1.B.5.A the number of tubes plugged in each Unit One Steam Generator as a result of the most recent inspection is as follows:

<u>Steam Generator</u>	<u>Total this Outage</u>		<u>Reason for Plug/Sleeve</u>	
	<u>Plugged</u>	<u>Sleeved</u>	<u>Tech. Spec. Required</u>	<u>Preventive</u>
(A) 1RC100	18	82	1	99
(B) 1RC400	50	138	28	160
(C) 1RC200	15	191	4	202
(D) 1RC300	11	34	9	35

Note that these totals do not include replugging of 28 hot leg tube ends due to Westinghouse plug removals for NRC Bulletin 89-01.

If there are any additional questions, please contact Mr. R. L. Sumners of the Zion Station Technical Staff.

Sincerely,

*T. A. Rieck*

T. A. Rieck  
 Technical Superintendent  
 Zion Station

*ew*

TAR/RLS/sac

cc: T. Rieck  
 R. Johnson  
 W. T'Niemi/L. Laspisa  
 R. Wulf/R. Sumners  
 T. VanDeVoort/G. Olson  
 G. Trzyna  
 J. Blomgren  
 R. Tamminga  
 Master File

IEU  
 1/0

8911070346 891026  
 FDR ADOCK 05000295  
 FDC

OCT 30 1989