



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

WOLF CREEK NUCLEAR OPERATING CORPORATION

WOLF CREEK GENERATING STATION

DOCKET NO. 50-482

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 34
License No. NPF-42

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment to the Wolf Creek Generating Station (the facility) Facility Operating License No. NPF-42 filed by the Wolf Creek Nuclear Operating Corporation (the Corporation), dated July 25, 1989, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, as amended, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this license amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

8911090090 891101
PDR ADOCK 05000482
P PDC


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and Paragraph 2.C.(2) of Facility Operating License No. NPF-42 is hereby amended to read as follows:

2. Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 34, and the Environmental Protection Plan contained in Appendix B, both of which are attached hereto, are hereby incorporated in the license. The Corporation shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. The license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION


Frederick J. Hebbon, Director
Project Directorate IV
Division of Reactor Projects - III,
IV, V and Special Projects
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: November 1, 1989

ATTACHMENT TO LICENSE AMENDMENT NO. 34

FACILITY OPERATING LICENSE NO. NPF-42

DOCKET NO. 50-482

Revise Appendix A Technical Specifications by removing the page identified below and inserting the enclosed page. The revised page is identified by amendment number and contains marginal lines indicating the areas of change. The corresponding overleaf page is also provided to maintain document completeness.

REMOVE PAGE

3/4 9-7

INSERT PAGE

3/4 9-7

REFUELING OPERATIONS

SURVEILLANCE REQUIREMENTS (Continued)

to the movement of fuel assemblies in the reactor vessel by performing a load test of at least 125% of the secondary automatic overload cutoff and demonstrating an automatic load cutoff when the refueling machine load exceeds the Setpoints of Specification 3.9.6a.2) and by demonstrating an automatic load reduction trip when the load reduction exceeds the Setpoint of Specification 3.9.6a.3).

4.9.6.2 Each auxiliary hoist and associated load indicator used for movement of drive rods within the reactor vessel shall be demonstrated OPERABLE within 100 hours prior to the movement of drive rods within the reactor vessel by performing a load test of at least 1250 pounds.

REFUELING OPERATIONS

3/4.9.7 CRANE TRAVEL - SPENT FUEL STORAGE FACILITY

LIMITING CONDITION FOR OPERATION

3.9.7 Loads in excess of 2250 pounds shall be prohibited from travel over fuel assemblies in the spent fuel storage facility.

APPLICABILITY: With fuel assemblies in the spent fuel storage facility.

ACTION:

- a. With the requirements of the above specification not satisfied, place the crane load in a safe condition.
- b. The provisions of Specifications 3.0.3 and 3.0.4 are not applicable.

SURVEILLANCE REQUIREMENTS

4.9.7 Crane interlocks and physical stops which prevent crane travel with loads in excess of 2250 pounds over fuel assemblies shall be demonstrated OPERABLE within 7 days prior to crane use and at least once per 7 days thereafter during crane operation.