



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

December 3, 2019

LICENSEE: EXELON GENERATION COMPANY, LLC

FACILITIES: BRAIDWOOD STATION, UNITS 1 AND 2; CALVERT CLIFFS NUCLEAR POWER PLANT, UNITS 1 AND 2; CLINTON POWER STATION, UNIT NO. 1; LIMERICK GENERATING STATION, UNITS 1 AND 2; NINE MILE POINT NUCLEAR STATION, UNITS 1 AND 2; PEACH BOTTOM ATOMIC POWER STATION, UNITS 2 AND 3; AND R. E. GINNA NUCLEAR POWER PLANT

SUBJECT: SUMMARY OF NOVEMBER 18, 2019, MEETING WITH EXELON GENERATION COMPANY, LLC REGARDING A PLANNED REQUEST FOR AN ALTERNATIVE TO SUPPLEMENTAL VALVE POSITION INDICATION TESTING REQUIREMENTS (EPID L-2019-LRM-0075)

On November 18, 2019, a Category 1 public meeting was held between the U.S. Nuclear Regulatory Commission (NRC) staff and representatives of Exelon Generation Company, LLC (Exelon, the licensee). The purpose of the meeting was to discuss a proposed alternative to the requirements in Title 10 of the *Code of Federal Regulations* (10 CFR) Section 50.55a, "Codes and standards," for supplemental position indication (SPI) testing of valves. The meeting notice and agenda are available in the Agencywide Documents Access and Management System (ADAMS) at Accession No. ML19308A051. A copy of Exelon's presentation is available in ADAMS at Accession No. ML19317C995. A list of attendees is enclosed.

The proposed alternative will be for the Exelon plants which are currently using, or will be using in 2020, the 2012 Edition of the American Society of Mechanical Engineers (ASME) Code for Operation and Maintenance of Nuclear Power Plants (OM Code). The ASME OM Code requires SPI testing of valves to be performed once every 2 years. In addition, 10 CFR 50.55a(b)(3)(xi) requires:

When implementing ASME OM Code, 2012 Edition, Subsection ISTC-3700, "Position Verification Testing," licensees shall verify that valve operation is accurately indicated by supplementing valve position indicating lights with other indications, such as flow meters or other suitable instrumentation, to provide assurance of proper obturator position.

Exelon is planning on submitting this alternative as a fleet request in December 2019. For plants that transition to the 2012 Edition of the ASME OM Code after 2020, Exelon would request a similar alternative on an individual plant bases with other relief requests that are typically submitted before the start of the next 10-year in-service testing interval.

The proposed alternative would not apply to active motor-operated valves tested in accordance with the Mandatory Appendix III, "Preservice and Inservice Testing of Active Electric Motor Operated Valve Assemblies in Light-Water Reactor Power Plants," of the ASME OM Code. In addition, Exelon stated that the proposed alternative would not apply to Anchor Darling double-

disc gate valves. The NRC staff stated that it would better to exclude valves with threaded connections, rather than explicitly excluding Anchor Darling valves.

Exelon stated that the SPI requirements or frequency would be adjusted using either component risk ranking results or crediting seat leakage testing to prove closure following NRC-approved performance-based frequencies. Under the latter method, the alternative test frequency would be consistent with the test frequencies in Appendix J, "Primary Reactor Containment Leakage Testing for Water-Cooled Power Reactors," to 10 CFR Part 50.

Under the risk ranking process, Exelon would only relax the SPI testing requirement or frequency for specific valves if the risk consequences or susceptibility to stem-to-disc separation are acceptably low and one of the predefined criteria for hardship are met. Exelon further described how it would determine risk ranking and susceptibility to failure. The NRC staff stated that Exelon should consider operational experience which indicates that most issues have been with valves exposed to untreated water or in high-energy systems.

Exelon confirmed that it would not extend the currently required SPI test interval (i.e., once every 2 years) for high-risk valves that are susceptible to failure. The NRC staff noted that it would consider extension of the SPI test interval for high-risk valves that have a low susceptibility to failure.

Exelon also provided examples of the hardship criteria. Exelon plans to submit its alternative request in accordance with 10 CFR 50.55a(z)(2). This regulation allows the NRC staff to authorize an alternative to 10 CFR 50.55a if the licensee demonstrates that compliance with specific requirements in 10 CFR 50.55a "would result in hardship or unusual difficulty without a compensating increase in the level of quality and safety." The staff stated that it will need to seek legal advice to determine if 50.55a(z)(2) would allow approval of predetermined hardship criteria or if the licensee must identify the specific hardship for each valve as part of the application. The staff further stated that requesting the alternative in accordance with 50.55a(z)(1), which requires the license to demonstrate the alternative provides an acceptable level of quality and safety, may be a better approach.

The NRC staff also noted that there is a draft code case that would provide similar relief if it is ever finalized and endorsed by the ASME OM Code Committee. One commenter from industry noted that it may be beneficial to finalize this code case.

Public meeting feedback forms were not received. Please direct any inquiries to me at 301-415-1380, or Blake.Purnell@nrc.gov.

/RA/

Blake Purnell, Project Manager
Plant Licensing Branch III
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket Nos. STN 50-456, STN 50-457, 50-317,
50-318, 50-461, 50-352, 50-353,
50-220, 50-410, 50-277, 50-278,
and 50-244

Enclosure:
List of Attendees

cc: Listserv

SUBJECT: SUMMARY OF NOVEMBER 18, 2019, MEETING WITH EXELON GENERATION COMPANY, LLC REGARDING A PLANNED REQUEST FOR AN ALTERNATIVE TO SUPPLEMENTAL VALVE POSITION INDICATION TESTING REQUIREMENTS (EPID L-2019-LRM-0075) DATED DECEMBER 3, 2019

DISTRIBUTION:

PUBLIC

RidsNrrDorLpl1 Resource
RidsNrrDorLpl3 Resource
RidsRgn1MailCenter Resource
RidsRgn3MailCenter Resource
RidsNrrLALRonewicz Resource
RidsNrrLASRohrer Resource
RidsAcrs_MailCTR Resource
RidsNrrPMBraidwood Resource
RidsNrrPMCalvertCliffs Resource

RidsNrrPMClinton Resource
RidsNrrPMLimerick Resource
RidsNrrPMNineMilePoint Resource
RidsNrrPMPeachBottom Resource
RidsNrrPMREGinna Resource
RidsNrrPMExelon Resource
RidsNrrDexEmib Resource
LBetancourt, NRR
MMcCoppin, EDO
MFarnan, NRR

ADAMS Accession Nos. ML19326A315 (Summary)
ML19326A326 (Pkg.) *via e-mail NRR-106

OFFICE	NRR/DORL/LPL3/PM	NRR/DORL/LPL3/LA	NRR/DORL/LPL3/BC	NRR/DORL/LPL3/PM
NAME	BPurnell	SRohrer	NSalgado	BPurnell
DATE	12/2/2019	12/2/2019	12/3/2019	12/3/2019

OFFICIAL RECORD COPY

LIST OF ATTENDEES

NOVEMBER 18, 2019, MEETING WITH EXELON GENERATION COMPANY, LLC

Name	Affiliation
Blake Purnell	NRC
Michael Farnan	NRC
Stewart Bailey	NRC
Ryan Sprengel	Exelon
Mark DiRado	Exelon
William Reynolds	Exelon
Glenn Weiss	Exelon
Marcellus Ruff	Exelon
Carl McIlheran	Exelon
Keven Meyers	Exelon
David Neff	Exelon
Jason Taken	Exelon
Todd Cervini	Exelon
Brandon Shultz	Exelon
Lisa Zurawski	Exelon
Dwi Murray	Exelon
Ken Nicely	Exelon
Richard Gropp	Exelon
Rick Villar	Exelon
Thomas Loomis	Exelon
Brad Fuller	Pennsylvania Department of Environmental Protection