

Docket No.: 50-302

AUG 11 1975

DISTRIBUTION:  
 NRC PDR  
 L PDR  
 LWR 2-3 Rdg  
 Docket File ✓  
 VAMoore  
 RHeineman  
 WMcDonald  
 LWR TCs  
 ELD  
 IE (3)  
 LEngle  
 EGoulbourne  
 TR BCs  
 LWR BCs  
 ACRS (16)

Mr. J. T. Rodgers  
 Assistant Vice President  
 and Nuclear Project Manager  
 Florida Power Corporation  
 P. O. Box 14042  
 St. Petersburg, Florida 33733

Dear Mr. Rodgers:

The NRC is presently requesting additional information as provided in the enclosure to this letter on a uniform basis to all applications which are presently scheduled to receive operating licenses within the same time frame as Crystal River, Unit 3.

The Licensing Project Manager, Mr. L. Engle, has already discussed the contents of the enclosure with you on several occasions during the past two weeks.

In order to maintain our licensing schedule, we will need your response to the enclosure by September 15, 1975 in order that our evaluation may be incorporated in Supplement 2 to the Safety Evaluation Report presently scheduled to be issued on October 14, 1975.

If you cannot meet the response date, please inform us within seven days after receipt of this letter so that we may revise our scheduling.

Please contact us if you have any questions regarding the enclosure provided.

Sincerely,

Original Signed By

*ASchw*

A. Schwencer, Chief  
 Light Water Reactors Branch 2-3  
 Division of Reactor Licensing

Enclosure:  
 Request for Additional  
 Information

*A.S.*

cc: See next page

SEARCHED	x7886/LWR2-3	C-LWR-3:RL			
SERIALIZED	LEngle:rm	ASchwencer			
INDEXED	8/8/75	8/8/75			



ENCLOSURE

REQUEST FOR ADDITIONAL INFORMATION

Provide the following qualification test program information for balance of plant Class IE equipment.

- A. Equipment Design specification requirements,
- B. Test Plan,
- C. Test Set-up,
- D. Test Procedures, and
- E. Acceptability

This information shall be provided for at least one item in each of the following groups of Class IE equipment including test results.

- A. Switchgear,
- B. Motor control centers,
- C. Valve operators (in containment),
- D. Motors,
- E. Logic Equipment,
- F. Cable, and
- G. Diesel Generator Control Equipment