

N. C. Moseley  
Region II

RR Files

FS&EB ACTION CONTROL FORM


A. Action Code CDR#144  
Name of Licensee and Facility Arkansas Pwr. & Light (Arkansas Nuclear One-  
UNIT 1)  
Docket No. or License No. 50-313  
Title CDR Evaluation and Followup  
Origin CDR Date Rec'd 7/9/73 & 7/16/73

B. FS&EB Branch Coordinator:  
Bryan \_\_\_\_\_ Dreher \_\_\_\_\_  
Ellis \_\_\_\_\_ Paulus X  
Completion Requested by \_\_\_\_\_

C. Action Requested of:  
ADREMP \_\_\_\_\_ M&PPOB \_\_\_\_\_ EPB \_\_\_\_\_ RPB \_\_\_\_\_ ADCO \_\_\_\_\_  
OB \_\_\_\_\_ CB \_\_\_\_\_ TAB \_\_\_\_\_ OOE \_\_\_\_\_ Region II  
Date Requested 7/27/73 Completion Requested by \_\_\_\_\_  
Reference Letter dated 6/15/73 from J. D. Phillips to F. E. Kruesi  
(received in HQ on 7/9/73) and ltr dtd 7/16/73 from Phillips to Kruesi

D. Action Requested  
In accordance with PI 0600/6, "Construction Deficiency Reporting", the Arkansas Power & Light Company (Arkansas Nuclear One - Unit 1) deficiency report of 6/15/73 and 7/16/73 covering deformed metal over cap screws on the main fuel handling bridge is being assigned to Region II for evaluation of the technical adequacy of the corrective action and the final resolution of the deficiency.

E. Date Action Completed \_\_\_\_\_  
Close-out (Date & Method) \_\_\_\_\_  
Comments: If completion date is not consistent with your work schedule, please let us know.

  
J. G. Davis, Deputy Director  
for Field Operations  
Directorate of Regulatory Operations