

Arkansas Power and Light Company
Arkansas Nuclear One, Unit 1
Docket No. 50-313/77-21

NOTICE OF VIOLATION

Based on the results of the NRC inspection conducted during the period November 14-18, 1977, it appears that certain of your activities were not conducted in full compliance with your Reactor License or NRC regulations as indicated below:

Technical Specification 6.8.1 states in part that, "written procedures shall be established, implemented and maintained covering the activities referenced below:

"a. The applicable procedures recommended in Appendix 'A' of Regulatory Guide 1.33, November 1972.

. . . .

"c. Surveillance and Test activities of safety-related equipment."

Procedure 1005.01, Administrative Controls Manual, Section 5.1, also states in part that, ". . . the manual is written for the purpose of having an up-to-date compilation of procedures necessary for the safe operation of the plant"

Contrary to the above requirements, procedures 1102.04, Power Operation, and 1004.12, Operational Test Control, had not been maintained in an up-to-date manner to reflect current operational and Technical Specification requirements.

This is an infraction.

8004150788