

Docket No. 50-313

ENCLOSURE NO. 1

NOTICE OF VIOLATION

Based on the results of the NRC inspection conducted on April 25-27, 1977, it appears that certain of your activities were not conducted in full compliance with NRC requirements as indicated below:

Technical Specification 6.7.1(i) requires that detailed written procedures shall be prepared and adhered to for the implementation of your Emergency Plans.

- A. Contrary to the above, a first aid room was not located near the Unit 2 controlled access entrance as stated in Section 4.3.2.a of your Emergency Plan.

This is an infraction.

- B. Contrary to the above, periodic annual reviews with local groups were not held between March 4, 1976 and April 27, 1977, for seven (7) of the 17 support groups listed in the Emergency Plan as stated in Section 5.4 of your Emergency Plan.

This is an infraction.

8004150828