

Arkansas Nuclear One, Unit 1  
Docket No. 50-313  
License No. DPR-51

APPENDIX A

NOTICE OF VIOLATION

Based on the results of the NRC inspection conducted during the period June 16-18, 1976, it appears that certain of your activities were not conducted in full compliance with your Reactor License or NRC Regulations as indicated below:

Technical Specification 6.7 requires that changes to procedures relating to surveillance and testing requirements of systems and components involving nuclear safety shall be reviewed by the Plant Safety Committee and approved by the Superintendent prior to implementation. Technical Specification 6.7 also requires that temporary procedures which do not change the intent of the procedure must be approved by two staff members, one of which must be a shift supervisor. Temporary procedures that change the intent must be approved by the Plant Superintendent.

Contrary to the above Surveillance test procedures 1104.02 and 1104.06 were changed without evidence of approval.

This item is an infraction.

8004160335