



UNITED STATES  
ATOMIC ENERGY COMMISSION

XXXXXXXXXXXXXXXXXXXXXXXXXXXX

REGION II - SUITE 518  
230 PEACHTREE STREET, NORTHWEST  
ATLANTA, GEORGIA 30303

TELEPHONE: (404) 526-4503

DIRECTORATE OF REGULATORY OPERATIONS

In Reply Refer To:  
RO:II:JGD  
50-313

June 30, 1972

Arkansas Power and Light Company  
Attn: Mr. J. D. Phillips  
Vice President and Chief Engineer  
Sixth and Pine Streets  
Pine Bluff, Arkansas 71601

Gentlemen:

This letter relates to your reactor Arkansas Nuclear One, Unit 1.

Information obtained during inspections conducted by the Directorate of Regulatory Operations, has disclosed that a number of facilities have been equipped with valves with wall thicknesses below the minimum requirements specified by the applicable codes, standards and procurement specifications. In other instances, licensees have not been able to document whether or not their valves met minimum wall thickness requirements. Our survey of this subject has disclosed that the matter is not limited to any class of licensee or valve supplier.

In light of the above information, you are requested to verify, through manufacturing records or other suitable means, that valves important to nuclear safety installed or to be installed at your facility meet the minimum wall thickness requirements of the specified codes or standards. To the extent that verification records are currently available, you are requested to promptly accumulate those records at the plant site, and to advise this office within thirty (30) days of the date of this letter, of what records are available and when our inspector may examine them at the plant site.

8004170571

June 30, 1972

In the event that records are not currently available, you are requested to advise this office within thirty (30) days, of your plans and schedules for demonstrating by suitable alternate means, that valves important to nuclear safety installed or to be installed at your facility are acceptable with respect to wall thickness. Records of conformance shall be maintained current with inspections performed.

The valves which require demonstration of acceptable wall thickness are the following:

Each valve within the reactor coolant pressure boundary, as defined in subsection 50.55(e) (Codes and Standards) of 10 CFR 50, where the valve is:

- (a) over 1-inch nominal pipe size for pressurized water reactors;
- (b) over 1 1/4-inch nominal pipe size in water lines for boiling water reactors;
- (c) over 2 1/2-inch nominal pipe size in steam lines for boiling water reactors.

The following techniques are considered to be a sufficient demonstration of acceptable wall thickness. Alternate techniques may be offered, but there is no assurance that they will be found acceptable:

- (1) Documented direct physical measurement of actual wall thickness, with comparison to specified minimum wall thickness.
- (2) Documented results of ultrasonic measurement of wall thickness, with comparison to specified minimum wall thickness, and documentation that the ultrasonic measurement technique is demonstrated to have a maximum error in repeatability and accuracy, of not more than 2% of the wall thickness.

- (3) Wall thicknesses, verified by either of the above techniques, to be not less than 90% of specified minimum wall thickness will be acceptable, provided that the documented mechanical characteristics of the material exceed the specification minimum by an amount sufficient to compensate for the measured reduction in wall thickness.
- (4) "Specified Minimum Wall Thickness" as used above, means the wall thickness required by the relevant codes and standards (e.g., ASA B31.1 (1955); USAS B31.1.0 (1967); USAS B16.5; MSS-SP-66) in effect on the date of the purchase order.
- (5) Certain of your valves may have, for procurement convenience, been ordered to ratings higher than actually required by service conditions. In such instances, you may, if you wish, provide for our review, an engineering justification for accepting valves which do not conform to procurement specifications, but do, in your opinion, satisfy service requirements. Such justification should be promptly transmitted to this office, in ten (10) copies.
- (6) In certain instances, you may wish to repair valves found to have wall thickness below the specified minimum. In such instances you are requested to provide to this office for our review, the proposed repair procedure, including a description of techniques to be used to verify the acceptability of the repaired components. Such a proposed procedure should also be submitted in ten (10) copies.

Acceptable documentation of conformance with the above requirements must be completed within three (3) years of the date of this letter.

Very truly yours,

Original Signed By  
J. G. Davis

John G. Davis  
Director