

DISTRIBUTION

NRC PDR
Local PDR
Docket
ORB #2 Reading
KRGoller
TJCarter
OELD
OI&E (3)
DLZiemann
WEConverse
RMDiggs
SVarga
DEisenhut
TBAbernathy, DTIE
ACRS (16)

NOV 06 1975

Docket No. 50-313

Arkansas Power & Light Company
ATTN: Mr. J. D. Phillips
Senior Vice President
Production, Transmission,
and Engineering
Sixth and Pine Streets
Pine Bluff, Arkansas 71601

Gentlemen:

Your license amendment application, dated October 7, 1975, requested changes to the Arkansas Nuclear One - Unit 1 facility Technical Specifications in three separate and unrelated areas: the Reactor Building Spray System tanks level and chemical concentration limits (pgs. 36, 37 and 39 of the Appendix A Technical Specifications), emergency pond limiting conditions for operation and surveillance requirements (pgs. 66a and 110a of the Appendix A Technical Specifications), and the Reactor Building tendon surveillance requirements (pg. 86 of the Appendix A Technical Specifications). Our preliminary review of the first item indicates significant changes from the present specifications regarding the chemical concentration limits for the sodium thiosulfate tank and the sodium hydroxide tank. Insufficient safety analysis was included with your letter to support this requested change. Consequently, we are discontinuing our review of this section of the application until appropriate analysis is provided. The other requested changes are presently under review.

Sincerely,

Original Signed by:
Dennis L. Ziemann

Dennis L. Ziemann, Chief
Operating Reactors Branch #2
Division of Reactor Licensing

cc: see next page

8004180551 P

KRG

cc-2
PZ

OFFICE →	RL:ORB #2	RL:ORB #2	RL:AD/ORs		
SURNAME →	WEConverse:ah	DLZiemann	KRGoller		
DATE →	11/06/75	11/06/75	11/6/75		

NOV 06 1975

Arkansas Power & Light Company

- 2 -

cc:

Horace Jewell
House, Holms & Jewell
1550 Tower Building
Little Rock, Arkansas 72201

Mr. William Cavanaugh, III
Production Department
Post Office Box 551
Little Rock, Arkansas 72203

Arkansas Polytechnic College
Russellville, Arkansas 72801