

UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

ARKANSAS POWER & LIGHT COMPANY

DOCKET NO. 50-313

ARKANSAS NUCLEAR ONE - UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 19 License No. DPR-51

- 1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Arkansas Power & Light Company (the licensee) dated October 6, 1976, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission:
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
- Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and Paragraph 2.c(2) of Facility Operating License No. DPR-51 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 19, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

Dennis L. Ziemann, Chief Operating Reactors Branch #2 Division of Operating Reactors

Attachment: Changes to the Technical Specifications

Date of Issuance: February 18, 1977

FACILITY OPERATING LICENSE NO. DPR-51 DOCKET NO. 50-313

Replace existing page 72 of the Appendix A portion of the Technical Specifications with the attached revised page 72. The changed area on the revised page is identified by a marginal line

	Channel Description	Check	Test	Calibrate
30.	Decay Heat Removal System Isolation Valve Automatic Closure and Interlock System	S(1)(2)	M(1)(3)	R
31.	Turbine Overspeed Trip Mechanism	NA	R	NA
32.	Steam Line Break Instrumentation And Control System Logic Test & Control Circuits	W	Q	R
33.	Diesel Generator Protective Relaying, Starting Interlocks And Circuitry	М	Q	NA
34.	Off-site Power Undervoltage And Protective Relaying Interlocks And Circuitry	W	R	R
35.	Borated Water Storage Tank Level Indicator	W	NA	R
36.	(Deleted)			

(1)	Includes	RCS	Pressure	Analog
	Channel			

Remarks

- (2) Includes CFT Isolation Valve Position
- (3) Shall Also Be Tested During
 Refueling Shutdown Prior to Repressurization at a pressure greater
 than 300 but less than 420 psig.