

Docket File

DEC 27 1972

Docket No. 50-313

Mr. J. D. Phillips
Vice President & Chief Engineer
Arkansas Power & Light Company
Sixth and Pine Streets
Pine Bluff, Arkansas 71601

Dear Mr. Phillips:

In almost every analysis of a nuclear power plant accident, safe recovery from the accident or containment of radioactive materials depends on the proper function of active valves. In many cases these valves would be required to operate properly while at high temperature, against maximum pressure differentials, and while subjected to a severe accident or seismic vibratory environment. The number of valve malfunctions that have been encountered during inservice tests in operating plants, suggests that we have not yet established adequate preservice and inservice test programs to assure the operability of active valves. In this light we have reviewed your response to our Request for Information 4.32, as it applies to active valves, and have concluded that the limited dynamic analytical and testing procedures used to confirm the operability of all active valves as specified are insufficient.

An acceptable program would be in-situ valve testing where the operability of valves is demonstrated in the plant during the preoperational testing of those systems designed to Seismic Category I criteria. You are requested to provide as an Amendment to your Application, the details of such a program which would demonstrate operability under normal system operation, as well as under superimposed loadings, that appropriately simulate seismic vibratory responses, and accident (LOCA) vibratory responses, as applicable to the system. This program may include either the application of vibratory devices to superimpose the vibratory seismic and accident loadings or an equivalent combination of analytical and testing methods that confirm operability. The test program may be based upon selectively testing a representative number of active valves in the piping system according to valve type, seismic and accident load level, size, etc. on a prototype basis.

8004180 643 A

LB

DEC 27 1972

J. D. Phillips

-2-

Because of the scope and the generic nature of the program requested, you are invited to discuss this request with the AEC staff at the earliest opportunity.

Sincerely,

Original Signed by
R. C. DeYoung

R. C. DeYoung, Assistant Director
for Pressurized Water Reactors
Directorate of Licensing

cc: Horace Jewell, Esquire
House, Holms & Jewell
1550 Tower Building
Little Rock, Arkansas 72201

DISTRIBUTION

<u>Docket File</u>	SHanauer
R Reading	RSBoyd
RP Reading	DSkovholt
PWR-4 Reading	FSchroeder
RBernero	DKnuth
ASchwencer	RTedesco
RMaccary	HDenton
RCDeYoung	PWR Branch Chiefs
	RWKlecker
	OGC
	RO (3)
	EIGoulbourne

OFFICE ▶	PWR-4	PWR-4		L:AD/PWR		
SURNAME ▶	<i>RB</i> RMBernero:kmf	<i>AS</i> ASchwencer	<i>RM</i> RMaccary	<i>RC</i> RCDeYoung		
DATE ▶	12/27/72	12/27/72	12/27/72	12/27/72		