

DISTRIBUTION:  
 Public Docket Room  
 Suppl. ←  
 DR Reading  
 DRL Reading  
 PWR-3 Reading  
 R. S. Boyd, DRL  
 R. C. DeYoung, DRL  
 F. Karas, DRL  
 L. Kornblith, CO (2)  
 DRL Branch Chiefs

Docket No. 50-313

APR 1 1970

Arkansas Power and Light Company  
 Pine Bluff, Arkansas 71601

Attention: Mr. J. D. Phillips  
 Vice President and Chief Engineer

Gentlemen:

This is to confirm our telephone notification to you of March 30, 1970, that you may proceed with the construction of the containment building for Arkansas Nuclear One up to, but not including, the ring girder between the wall and the dome. Before we can approve construction beyond this point, we will require the information requested by my letter of January 26, 1970, on the design and analysis of the containment buttress adjacent to the ring girder at the dome.

The information provided in Supplement No. 16 to your application in response to our request for information on the design and analysis of the containment walls and buttresses will also have to be supplemented. In order to facilitate this, a meeting will be arranged to enable discussion of the information you provided in Supplement 16.

Sincerely yours,

Original signed by F. Schroeder *FS*

Peter A. Morris, Director  
 Division of Reactor Licensing

cc: Mr. Harlan T. Holmes  
 Mr. Horace Jewell  
 Mr. Roy B. Snapp

bcc: P. A. Morris, DRL  
 F. Schroeder, DRL  
 R. C. DeYoung, DRL  
 K. R. Goller, DRL  
 R. A. Birkel, DRL

8004180664, A

OFFICE ▶	DRL: PWR-3	DRL: PWR-3	DRL: AD/PWR's	DRL: D/AD	DRL: DIB	
SURNAME ▶	<i>RAB</i> RABirkel:esp	<i>KRG</i> KRGoller	<i>RCDeYoung</i> RCDeYoung	<i>FS</i> FSchroeder	<i>FS</i> PAMorris	
DATE ▶	4/3/170	3/31/70	4/1/70	4/7/70	4/1/70	