

AUG 05 1975

Docket No. 50-313

Arkansas Power & Light Company
ATTN: Mr. J. D. Phillips
Senior Vice President
Production, Transmission
and Engineering
Sixth and Pine Streets
Pine Bluff, Arkansas 71601

DISTRIBUTION

Docket
NRC PDR
Local PDR
ORB#2 Reading
KRGoller
TJCarter
DLZiemann
WEConverse
OELD

OI&E (3)
ACRS (14)
MBFairtile
DEisenhut
LDiggs (2)

Re: Arkansas Nuclear One -
Unit 1

Gentlemen:

10 CFR Part 50, Appendix J, "Primary Reactor Containment Leakage Testing for Water-Cooled Power Reactors," was published February 14, 1973. Since many nuclear plants had either received an operating license or their containments had reached advanced stages of design or construction at that time, some plants may not now be in full compliance with the requirements of this regulation.

You are requested to determine if you are conducting containment leakage testing in full compliance with Appendix J. This determination should include the identification of any design features that do not permit conformance with its requirements or existing technical specification requirements which are in conflict with Appendix J (i.e. less restrictive than). It should be understood that while a containment leakage testing program may be in compliance with the technical specifications for your facility, the program may not be in conformance with Appendix J.

If you are not in full compliance, you should identify your planned actions and schedule to attain conformance to the Regulation. Possible courses of action include design modifications, amendments to the technical specifications, and requests for exemption pursuant to 10 CFR Part 50, Section 50.12.

Please submit the results of your study to us as soon as possible but no later than 30 days from receipt of this letter.

This request for generic information was approved by GAO under a blanket clearance number E-180225 (L0072); this clearance expires July 31, 1977.

Sincerely,

Original signed by R. A. Purple

Carl F. Goller, Assistant Director

R.A. Purple

OFFICE	Enclosure: Appendix J	RL:ORB#2 WEConverse:tc 8/01/75	RL:ORB#2 DLZiemann 8/5/75	RL:AD/ORS KRGoller 8/5/75
--------	--------------------------	--------------------------------------	---------------------------------	---------------------------------

8004180669 P

AUG 05 1975

cc w/enclosure:

Horace Jewell

House, Holms & Jewell

1550 Tower Building

Little Rock, Arkansas 72201

Mr. William Cavanaugh, III

Production Department

Post Office Box 551

Little Rock, Arkansas 72203

Arkansas Polytechnic College

Russellville, Arkansas 72801

Title 10—Atomic Energy
CHAPTER I—ATOMIC ENERGY
COMMISSION

PART 50—LICENSING OF PRODUCTION
AND UTILIZATION FACILITIES

Reactor Containment Leakage Testing for
Water-Cooled Power Reactors

On August 27, 1971, the Atomic Energy Commission published in the *FEDERAL REGISTER* (36 FR 17053) a proposed amendment to its regulations in 10 CFR Part 50 which would specify the minimum containment leakage test requirements for water-cooled power reactors.

Interested parties were invited to submit written comments and suggestions for consideration in connection with the proposed amendment within 60 days after publication in the *FEDERAL REGISTER*. Upon consideration of the comments received, and other factors involved, the Commission has adopted the proposed amendment, with certain modifications in the form set forth below.

Significant differences from the amendment published for comment are: (1) Modification of procedures governing containment inspection and leak detection surveys, as a prerequisite to conducting formal leakage tests, and clarification of the basis for reporting pretest leakage values to the Commission, (2) establishment of criteria for deferring certain safety-related systems from regularly scheduled Type A containment leakage tests, (3) incorporation by reference of the recently-issued American National Standard for leakage rate testing of containment structures for nuclear reactors into the regulation, (4) inclusion of nitrogen gas as a suitable testing medium for testing the leaktightness of valves, and (5) inclusion of water-leakage test and acceptance criteria for containment isolation valves which are sealed against containment atmosphere outleakage during a design basis accident condition by means of a seal-water system. In addition, editorial and format changes were made.

With regard to item (1) above, the rule set forth below requires the licensee to identify specifically those components whose initial poor leak-tightness performance precluded completion of a Type A containment leakage test and to report this information to the Commis-

sion. The proposed rule would not have required the reporting of such information unless attempts to reduce the leakage rate of poor leak-tight components failed to meet minimum leak-tightness acceptance criteria. Thus, components which required frequent adjustments or repair in order to meet allowable leakage limits will be identified and the specific reductions in leakage rate values, resulting from such adjustments, will be reported to the Commission. The identification of such components will provide the AEC with a sounder basis for judging whether or not containment leakage rates could have been exceeded in the unlikely event a design basis accident were to occur. In addition, such identification may provide insight into the frequency and kinds of adjustments being made to components to meet the minimum acceptable leakage limits and a basis for either establishing a more frequent containment leakage test schedule, or modifying or replacing components.

With regard to item (2) above, the rule set forth below specifies criteria by which the licensee may for certain safety-related systems temporarily dispense with drainage and venting to containment atmosphere during Type A containment leakage tests. The proposed rule had specified that all systems which would connect directly with the containment atmosphere and would become an extension of the containment boundary should be vented to containment. Strict compliance with this rule would have required removing certain safety-related systems from service for the duration of the test and would limit the performance of the overall integrated containment leakage tests to those times when there would be no fuel in the reactor. This procedure is considered to be unnecessarily conservative.

The inclusion of all safety-related systems in the overall integrated containment leakage test can be accomplished while the reactor is fueled, and in a state of potential criticality, by maintaining the minimum number of safety-related systems in an operable state until all systems are tested. Another option is to periodically test the containment isolation valves in these safety-related systems in accordance with the rule set forth below. This would also assure that the requisite level of plant safety will be provided during the containment leakage test program without compromising the requirements for including all systems which penetrate the containment boundary in the leakage test.

The proposed rule required the use of test methods described in proposed American Nuclear Society Standard ANS 7.60 by referencing a portion of the proposed standard. On March 16, 1972, the American National Standards Institute approved ANS 7.60 and officially issued it for use as ANSI N45.4-1972, American National Standard, "Leakage Rate Testing of Containment Structures for Nuclear Reactors." The standard has been reviewed for compatibility with the proposed rule and it was concluded that incorporation of the requirements of ANSI

from testing the containment with components and systems in the state as close as practical to that which would exist under design basis accident conditions (e.g., vented, drained, flooded or pressurized).

O. "Acceptance criteria" means the standard against which test results are to be compared for establishing the functional acceptability of the containment as a leakage limiting boundary.

III. LEAKAGE TESTING REQUIREMENTS

A program consisting of a schedule for conducting Type A, B, and C tests shall be developed for leak testing the primary reactor containment and related systems and components penetrating primary containment pressure boundary.

Upon completion of construction of the primary reactor containment, including installation of all portions of mechanical, fluid, electrical, and instrumentation systems penetrating the primary reactor containment pressure boundary, and prior to any reactor operating period, preoperational and periodic leakage rate tests, as applicable, shall be conducted in accordance with the following:

A. Type A test—1. Pretest requirements.

(a) Containment inspection in accordance with V.A. shall be performed as a prerequisite to the performance of Type A tests. During the period between the initiation of the containment inspection and the performance of the Type A test, no repairs or adjustments shall be made so that the containment can be tested in as close to the "as is" condition as practical. During the period between the completion of one Type A test and the initiation of the containment inspection for the subsequent Type A test, repairs or adjustments shall be made to components whose leakage exceeds that specified in the technical specification as soon as practical after identification. If during a Type A test, including the supplemental test specified in III.A.3.(b), potentially excessive leakage paths are identified which will interfere with satisfactory completion of the test, or which result in the Type A test not meeting the acceptance criteria III.A.4.(b) or III.A.5.(b), the Type A test shall be terminated and the leakage through such paths shall be measured using local leakage testing methods. Repairs and/or adjustments to equipment shall be made and a Type A test performed. The corrective action taken and the change in leakage rate determined from the tests and overall integrated leakage determined from the local leak and Type A tests shall be included in the report submitted to the Commission as specified in V.B.

(b) Closure of containment isolation valves for the Type A test shall be accomplished by normal operation and without any preliminary exercising or adjustments (e.g., no tightening of valve after closure by valve motor). Repairs of malfunctioning or leaking valves shall be made as necessary. Information on any valve closure malfunction or valve leakage that requires corrective action before the test, shall be included in the report submitted to the Commission as specified in V.B.

(c) The containment test conditions shall stabilize for a period of about 4 hours prior to the start of a leakage rate test.

(d) Those portions of the fluid systems that are part of the reactor coolant pressure boundary and are open directly to the containment atmosphere under post-accident conditions and become an extension of the boundary of the containment shall be opened or vented to the containment atmosphere prior to and during the test. Portions of closed systems inside containment that penetrate containment and rupture as a result of a loss of coolant accident shall be vented to the containment atmosphere. All vented sys-

tems shall be drained of water or other fluids to the extent necessary to assure exposure of the system containment isolation valves to containment air test pressure and to assure they will be subjected to the post-accident differential pressure. Systems that are required to maintain the plant in a safe condition during the test shall be operable in their normal mode, and need not be vented. Systems that are normally filled with water and operating under post-accident conditions, such as the containment heat removal system, need not be vented. However, the containment isolation valves in the systems defined in III.A.1.(d) shall be tested in accordance with III.C. The measured leakage rate from these tests shall be reported to the Commission.

2. **Conduct of tests.** Preoperational leakage rate tests at either reduced or at peak pressure, shall be conducted at the intervals specified in III.D.

3. **Test methods.** (a) All Type A tests shall be conducted in accordance with the provisions of the American National Standard N454-1972, Leakage Rate Testing of Containment Structures for Nuclear Reactors, March 16 1972.¹ The method chosen for the initial test shall normally be used for the periodic tests.

(b) The accuracy of any Type A test shall be verified by a supplemental test. An acceptable method is described in Appendix C of ANSI N454-1972. The supplemental test method selected shall be conducted for sufficient duration to establish accurately the change in leakage rate between the Type A and supplemental test. Results from this supplemental test are acceptable provided the difference between the supplemental test data and the Type A test data is within 0.25 La (or 0.25 Lt). If results are not within 0.25 La (or 0.25 Lt), the reason shall be determined, corrective action taken, and a successful supplemental test performed.

(c) Test leakage rates shall be calculated using absolute values corrected for instrument error.

4. Preoperational leakage rate tests. (a) **Test pressure—**(1) **Reduced pressure tests.**

(i) An initial test shall be performed at a pressure Pt, not less than 0.50 Pa to measure a leakage rate Ltm.

(ii) A second test shall be performed at pressure Pa to measure a leakage rate Lam.

(iii) The leakage characteristics yielded by measurements Ltm and Lam shall establish the maximum allowable test leakage rate Lt of not more than La (Ltm/Lam). In the event Ltm/Lam is greater than 0.7, Lt shall be specified as equal to La (Pt/Pa)^{1/2}.

(2) **Peak pressure tests.** A test shall be performed at pressure Pa to measure the leakage rate Lam.

(b) **Acceptance criteria—**(1) **Reduced pressure tests.** The leakage rate Ltm shall be less than 0.75 Lt.

(2) **Peak pressure tests.** The leakage rate Lam shall be less than 0.75 La and not greater than Ld.

5. **Periodic leakage rate tests—**(a) **Test pressure.** (1) Reduced pressure tests shall be conducted at Pt.;

(2) Peak pressure tests shall be conducted at Pa.

(b) **Acceptance criteria—**(1) **Reduced pressure tests.** The leakage rate Ltm shall be less than 0.75 Lt. If local leakage measurements are taken to effect repairs in order to meet the acceptance criteria, these measurements shall be taken at a test pressure Pt.

(2) **Peak pressure tests** shall be conducted Lam shall be less than 0.75 La. If local leakage measurements are taken to effect repairs in order to meet the acceptance criteria, these measurements shall be taken at a test pressure Pa.

6. **Additional Requirements.** (a) If any periodic Type A test fails to meet the applicable acceptance criteria in III.A.5.(b), the test schedule applicable to subsequent Type A tests will be reviewed and approved by the Commission.

(b) If two consecutive periodic Type A tests fail to meet the applicable acceptance criteria in III.A.5.(b), notwithstanding the periodic retest schedule of III.D., a Type A test shall be performed at each plant shutdown for refueling or approximately every 18 months, whichever occurs first, until two consecutive Type A tests meet the acceptance criteria in III.A.5.(b), after which time the retest schedule specified in III.D. may be resumed.

B. Type B tests.

1. **Test methods.** Acceptable means of performing a preoperational and periodic Type B tests include:

(a) Examination by halide leak-detection method (or by other equivalent test methods such as mass spectrometer) of a test chamber, pressurized with air, nitrogen, or pneumatic fluid specified in the technical specifications or associated bases and constructed as part of individual containment penetrations.

(b) Measurement of the rate of pressure loss of the test chamber of the containment penetration pressurized with air, nitrogen, or pneumatic fluid specified in the technical specifications or associated bases.

(c) Leakage surveillance by means of a permanently installed system with provisions for continuous or intermittent pressurization of individual or groups of containment penetrations and measurement of rate of pressure loss of air, nitrogen, or pneumatic fluid specified in the technical specification or associated bases through the leak paths.

2. **Test Pressure.** All preoperational and periodic Type B tests shall be performed by local pneumatic pressurization of the containment penetrations, either individually or in groups, at a pressure not less than Pa.

3. **Acceptance criteria.** (See also Type C tests.) (a) The combined leakage rate of all penetrations and valves subject to Type B and C tests shall be less than 0.60 La, with the exception of the valves specified in III.C.3.

(b) Leakage measurements obtained through component leakage surveillance systems (e.g., continuous pressurization of individual containment components) that maintains a pressure not less than Pa at individual test chambers of containment penetrations during normal reactor operation, are acceptable in lieu of Type B tests.

C. Test C tests.

1. **Test method.** Type C tests shall be performed by local pressurization. The pressure shall be applied in the same direction as that when the valve would be required to perform its safety function, unless it can be determined that the results from the tests for a pressure applied in a different direction will provide equivalent or more conservative results. The test methods in III.B.1 may be substituted where appropriate. Each valve to be tested shall be closed by normal operation and without any preliminary exercising or adjustments (e.g., no tightening of valve after closure by valve motor).

¹ ANSI N454-1972 Leakage Rate Testing of Containment Structures for Nuclear Reactors (dated Mar. 16, 1972). Copies may be obtained from the American Nuclear Society, 244 East Ogden Avenue, Hinsdale, IL 60521. A copy is available for inspection at the Commission's Public Document Room, 1717 H Street NW, Washington, DC. The incorporation by reference was approved by the Director of the Federal Register on October 30, 1972.