

LICENSEE EVENT REPORT

CONTROL BLOCK:

--	--	--	--	--	--

 1 6

(PLEASE PRINT ALL REQUIRED INFORMATION)

LICENSEE NAME										LICENSE NUMBER										LICENSE TYPE					EVENT TYPE		
01										0	0	-	0	0	0	0	0	-	0	0	4	1	1	1	1	0	1
7	8	9							14	15									25	26					30	31	32

01		CON'T		CATEGORY		REPORT TYPE		REPORT SOURCE		DOCKET NUMBER				EVENT DATE				REPORT DATE							
7	8	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80
				T	L	0	5	0	-	0	3	1	3	0	3	2	5	7	6	0	4	0	8	7	6

[illegible]

02	While making preparation for removing surveillance specimens for inspection of holder	80
03	tubes due to wear at other B&W plants, it was found that spring cartridge was missing	80
04	from 2 tubes and one of those two tubes was partially missing along with push rod	80
05	and journal bearing. Search for missing pieces initiated.(50-313/76-3)	80
06		80

SYSTEM CODE		CAUSE CODE		COMPONENT CODE						COMPONENT SUPPLIER		COMPONENT MANUFACTURER				VIOLATION	
07		C	A							N							N
7	8	9	10							43							48

CAUSE DESCRIPTION

08	NA	
7 8 9		80
09		80
7 8 9		80

FACILITY STATUS		% POWER			OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION	
11	6	0	0	0	NA	C		NA		
7	8	9	10	12	13	44	45	46	80	
FORM OF ACTIVITY RELEASED		CONTENT OF RELEASE		AMOUNT OF ACTIVITY		LOCATION OF RELEASE				
12	7	7		NA				NA		
7	8	9	10	11	44	45			80	

PERSONNEL EXPOSURES

NUMBER				TYPE	DESCRIPTION
1	3			7	NA

PERSONNEL INJURIES

NUMBER			DESCRIPTION
14	0	0	NA

OFFSITE CONSEQUENCES

15	NA
----	----

LOSS OR DAMAGE TO FACILITY

TYPE		DESCRIPTION
16	L	Extension of shutdown approximately 2 months to defuel, inspect, and refuel

PUBLICITY

17 | Press release made on 4/8/76

ADDITIONAL FACTORS

18	NA
----	----

19 8004180751

NAME: Daniel H. Williams

PHONE: (501) 371-4192

1. Reportable Occurrence Report No. 50-313/76-2
2. Report Date: 4/8/76 3. Occurrence Date: 3/25/76
4. Facility: Arkansas Nuclear One-Unit 1
Russellville, Arkansas 72801
5. Identification of Occurrence:

Reactor surveillance specimen holder tube failure.

6. Conditions Prior to Occurrence:

Steady-State Power	_____	Reactor Power	0	MWth
Hot Standby	_____	Net Output	0	MWe
Cold Shutdown	X	Percent of Full Power	0	%
Refueling Shutdown	_____	Load Changes During Routine Power Operation	_____	
Routine Startup Operation	_____			
Routine Shutdown Operation	_____			
Other (specify)				

7. Description of Occurrence:

At approximately 2200 hour while making preparation for removing the surveillance specimens for the inspection of the specimen holder tubes due to wear problems at two other B&W plants, it became apparent that the spring cartridge was missing from 2 of 3 specimen tubes. In addition one of those tubes, identified as tube no. 3, had the push rod missing and detached from the specimen, the journal bearing missing, and part, if not all, of the holder tube missing from the top of the shroud to the upper hinge of the specimen tube.

Tube no. 2 is in the same condition as tube no. 3 except that part, if not all, of the push rod is attached to the specimen and part, if not all, of the holder tube is still around the push rod. All of tube no. 1 was intact and the specimen has been removed. A 6½ foot section of holder tube came out when the specimen was removed. The specimens for tubes no. 2 and 3 appear to be in their proper location.

Reportable Occurrence Report No. 50-313/76-3

8. Designation of Apparent Cause of Occurrence:

Design	<u> x </u>	Procedure	<u> </u>
Manufacture	<u> </u>	Unusual Service Condition	<u> </u>
Installation/ Construction	<u> </u>	Including Environmental	<u> </u>
Operator	<u> </u>	Component Failure	<u> </u>
Other (specify)	<u> </u>		

9. Analysis of Occurrence:

There is no evidence of failed fuel due to what appears to be loose parts in the reactor, thus no hazard to the health and safety of the public.

Reportable Occurrence Report No. 50-313/76-3

10. Corrective Action:

The reactor will be defueled, the internals removed, loose parts retrieved, and necessary modifications and inspections made to prevent reoccurrence.

11. Failure Data:

No prior failures of this type at ANO.