Docket No. 50-313

JUN 9 1977

Arkansas Power & Light Company
ATTN: Mr. J. D. Phillips
Senior Vice President
Production, Transmission
and Engineering
Sixth and Pine Streets
Pine Bluff, Arkansas 71601

Gentlemen:

By letter dated June 3, 1977, you requested immediate changes to the Arkansas Nuclear One - Unit No. 1 (ANO-1) Technical Specifications to allow additional time (beyond 36 hours) for the repair of a failed reactor building emergency cooling fan. Such a change, to allow continued ANO-1 operation up to 7 days with one (1) of four (4) cooling fans inoperable, was issued as an emergency technical specification change on the evening of June 3, 1977. Our bases for issuance were: (1) the ANO-1 technical specifications were more stringent with regard to cooling fan requirements than need be, since the ANO-1 Final Safety Analysis Report (FSAR) stated that only one (1) spray pump and two (2) cooler fans were needed for pressure reduction; and (2) the latest regulatory guidance, in the form of Standard Technical Specifications, allows a certain period of time for operation in which certain safety-related equipment (including the spray pumps and fan coolers) may be out-of-service.

On June 7, 1977, prior to our preparation and formal issuance of the aforementioned Technical Specification amondment, you notified us by letter that no Loss-of-Coelant Accident (LOCA) - qualified replacement motor for the failed fan could be located in the United States or Europe. You requested additional changes to the Technical Specifications in order to operate indefinitely with one fan cooler out-of-service. We required an analysis in support of this request and specified that you must assume post-LOCA failure-to-start of one dissel generator system, with consequent loss of one sarray system and two coeler fans, concurrent with the already out-of-service fan. In this condition, with one spray system and one cooler fan in operation, containment integrity and pressure reduction criteria must be met.

const.

Your analysis forwarded by letter dated June 8, 1977, as supplemented by our own fatensive review, has shown that the aforementioned criteria are indeed met. Therefore, we have issued the enclosed Amendment No. 26 to Facility Operating License No. DPR-51 for the ANO-1 facility.

Copies of our related Safety Evaluations (June 3, 1977, and for the anclosed action) and the Notice of Issuance are also enclosed.

Singing Wated by

Don K. Davis, Acting Chief Operating Reactors Branch #2 Division of Operating Reactors

Enclosures:

Amendment No. 96 to License No. DPR-51

Safety Evaluations

Notice

17 Jon July (APE)

DISTRIBUTION=

Docket NRC PDR Local PDR

ORB #2 Reading

VSTello. KRG011er

RMDiggs RRSnaider

ELConner OELD

018E (5) BJones 4

BScharf- /

JMcGough .

BHarless

DEisenhut

WButler OPA aclare Miles

DRoss

ACRS (16)

TBAbernathy

JRBuchanan*

DOR: ORB #2 DOR: OT POR: PSB/OT OELD RPSnaider:ro RMDiggs DEisenhut WButler.

cc w/enclosures: Horace Jewell, Esquire House, Holms & Jewell 1550 Tower Building Little Rock, Arkansas 72201

Phillip K. Lyon, Esquire House, Holms & Jewell 1550 Tower Building Little Rock, Arkansas 72201

Mr. Donald Rueter Manager, Licensing Arkansas Power & Light Company Post Office Box 351 Little Rock, Arkansas 72201

Arkansas Polytechnic College Russellville, Arkansas 72801

Chief, Energy Systems Analyses Branch (AW-459) Office of Radiation Programs U. S. Environmental Protection Agency Room 645, East Tower 401 M Street, S. W. Washington, D. C. 20460

U. S. Environmental Protection Agency

First International Building
Dallas, Texas 75270

Honorable Ermil Grant
Acting County Judge of Pope County — 4/4, 5 6/3/77, authority
Pope County Courthouse
Russellville, Arkansas 72001

cc w/enclosures and a copy of AP&L letters dated June 3, 7 & 8. Director, Bureau of Environemtanl

Health Services 4815 West Markham Street Little Rock, Arkansas 72201

6/3/77anta.)

w/cy of 6/3/77 auth