



HELPING BUILD ARKANSAS

ARKANSAS POWER & LIGHT COMPANY

9TH & LOUISIANA STREETS • LITTLE ROCK, ARKANSAS 72203 • (501) 371-4000

May 13, 1976



Mr. E. Morris Howard, Director  
Office of Inspection & Enforcement  
Region IV  
U. S. Nuclear Regulatory Commission  
611 Ryan Plaza Drive, Suite 1000  
Arlington, Texas 76012

Subject: Arkansas Power & Light Company  
Arkansas Nuclear One-Unit 1  
Docket No. 50-313  
License No. DPR-51  
Reportable Occurrence No. 50-313/76-6

Dear Mr. Howard:

On May 5, 1976, we reported to you an occurrence at Arkansas Nuclear One-Unit 1 concerning the failure of the fuel handling area ventilation system to be in operation during fuel handling activities. Attached find our report on this incident in accordance with Technical Specification 6.12.3.1.

Very truly yours,

J. D. Phillips  
Senior Vice President

JDP:tw

cc: Mr. E. Volgenau, Director  
Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Mr. W. D. MacDonald, Director  
Office of Management Information  
and Program Control  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

8004180724 S

COPY SENT REGION

