

Docket No. 50-313

THIS DOCUMENT CONTAINS
POOR QUALITY PAGES

SEP 22 1977

Arkansas Power & Light Company
ATTN: Mr. William Cavanaugh, III
Executive Director, Generation
and Construction
P. O. Box 551
Little Rock, Arkansas 72203

DISTRIBUTION:
Docket Dross
NRC PDR T'Abernathy
L PDR J'Buchanan
ORB#2 Rdg
OELD
OIE&E (3)
DDavis
RSnaider
RDiggs
BGrimes
JmcGough
DEisenhut
ACRS (16)
BJones (4)
BScharf (15)
CHeborn
BHarless
OPA (CMiles)

Gentlemen:

By teletype dated August 26, 1977, you requested an emergency change to the Technical Specifications for Arkansas Nuclear One - Unit No. 1 (ANO-1). The purpose of the change was to allow continued operation of ANO-1 for up to 30 days with the hydrogen purge system inoperable. The change was authorized by telephone call and teletype of the authorization letter, both of August 26, 1977.

This letter formally transmits Amendment 27 to Facility Operating License DPR-51 to incorporate the changes made as mentioned above.

Copies of our related Safety Evaluation and the Notice of Issuance are enclosed.

Sincerely,

Don K. Davis

Don K. Davis, Acting Chief
Operating Reactors Branch #2
Division of Operating Reactors

Enclosures:

- 1. Amendment No. 27 to DPR-51
- 2. Safety Evaluation
- 3. Notice

cc w/enclosures: See next page

8004180758 P

OK provided paragraphs #2 and #3 on 9/20 of SE are removed DONE 9/19/77

60

OFFICE	ORB#2: DOR	ORB#2: DOR	EEB#OT: DOR	STSVOR: DOR	OELD	ORB#2: DOR
SURNAME	Rdiggs	RSnaider: nm	BGrimes	McGough	Chastend	DDavis
DATE	9/18/77	9/7/77	9/16/77	9/1/77	9/20/77	9/22/77



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

September 22, 1977

Docket No. 50-313

Arkansas Power & Light Company
ATTN: Mr. William Cavanaugh, III
Executive Director, Generation
and Construction
P. O. Box 551
Little Rock, Arkansas 72203


Gentlemen:

By teletype dated August 26, 1977, you requested an emergency change to the Technical Specifications for Arkansas Nuclear One - Unit No. 1 (ANO-1). The purpose of the change was to allow continued operation of ANO-1 for up to 30 days with the hydrogen purge system inoperable. The change was authorized by telephone call and teletype of the authorization letter, both of August 26, 1977.

This letter formally transmits Amendment 27 to Facility Operating License DPR-51 to incorporate the changes made as mentioned above.

Copies of our related Safety Evaluation and the Notice of Issuance are enclosed.

Sincerely,


Don K. Davis, Acting Chief
Operating Reactors Branch #2
Division of Operating Reactors

Enclosures:

1. Amendment No. 27 to DPR-51
2. Safety Evaluation
3. Notice

cc w/enclosures: See next page