

LICENSEE EVENT REPORT

CONTROL BLOCK:

[PLEASE PRINT ALL REQUIRED INFORMATION]

LICENSEE NAME: 01 ARARKI LICENSE NUMBER: 00-000000-00 LICENSE TYPE: 41111 EVENT TYPE: 03

CATEGORY: 01 CONT REPORT TYPE: L REPORT SOURCE: L DOCKET NUMBER: 050-0313 EVENT DATE: 072276 REPORT DATE: 081176

EVENT DESCRIPTION

02 DURING STEADY-STATE POWER OPERATIONS (99% FP) WHILE REVIEWING FLOW CHART, A
03 FAILURE TO PERFORM SURVEILLANCE TEST ON CONTROL ROOM EMERGENCY VENTILATION
04 SYSTEM AT THE REQUIRED FREQUENCY WAS NOTED. NOT A REPETITIVE
05 OCCURRENCE. REQUIRED SURVEILLANCE COMPLETED ON 7-23-76.
06 (50-313/76-19)

SYSTEM CODE: 07 SG CAUSE CODE: A COMPONENT CODE: ZZZZZZ PRIME COMPONENT SUPPLIER: Z COMPONENT MANUFACTURER: Zaaz VIOLATION: Y

CAUSE DESCRIPTION

08 IMPROPER ADMINISTRATIVE CONTROLS. REQUIRED SURVEILLANCE COMPLETED ON
09 7-23-76 AND SYSTEM PROVED OPERABLE. ALL SHIFT SUPERVISORS WERE
10 INFORMED OF THE OCCURRENCE AND INSTRUCTED TO FOLLOW SCHEDULE.

FACILITY STATUS: 11 E % POWER: 099 OTHER STATUS: NA METHOD OF DISCOVERY: B DISCOVERY DESCRIPTION: NA

FORM OF ACTIVITY RELEASED: 12 Z CONTENT OF RELEASE: Z AMOUNT OF ACTIVITY: NA LOCATION OF RELEASE: NA

PERSONNEL EXPOSURES
 NUMBER: 13 000 TYPE: Z DESCRIPTION: NA

PERSONNEL INJURIES
 NUMBER: 14 000 DESCRIPTION: NA

OFFSITE CONSEQUENCES
15 NA

LOSS OR DAMAGE TO FACILITY
 TYPE: 16 Z DESCRIPTION: NA

PUBLICITY
17 NA

ADDITIONAL FACTORS
18 NA

19

NAME: DAVID G. HARDS PHONE: (501) 371-4496

8004180 773

POOR ORIGINAL

1. Reportable Occurrence Report No. 50-313/76-19

2. Report Date: 8-11-76

3. Occurrence Date: 7-22-76

4. Facility: Arkansas Nuclear One - Unit 1
Russellville, Arkansas

5. Identification of Occurrence:

Failure to perform surveillance test on control room emergency ventilation system at the required frequency.

6. Conditions Prior to Occurrence:

Steady-State Power x

Reactor Power 2540 MWth

Hot Standby

Net Output 807 MWe

Cold Shutdown

Percent of Full Power 99 %

Refueling Shutdown

Load Changes During Routine Power Operation

Routine Startup Operation

Routine Shutdown Operation

Other (specify)

7. Description of Occurrence:

During review of flow charts, it was noted that surveillance on control room emergency air conditioning was overdue (scheduled date was 7-12-76), which was in violation of Technical Specification 4.10.

8. Designation of Apparent Cause of Occurrence:

Design	_____	Procedure	_____
Manufacture	_____	Unusual Service Condition Including Environmental	_____
Installation/ Construction	_____	Component Failure	_____
Operator	_____		
Other (specify)	<u> X </u>		
Administrative Control			

9. Analysis of Occurrence:

Surveillance was completed 7-23-76 and the system proven operable. Since the surveillance proved the system was operable, there was no hazard to the health and safety of the public.

Reportable Occurrence Report No. 50-313/ 76-19

10. Corrective Action:

All shift supervisors were made aware of the occurrence and instructed to pay closer attention to schedule.

11. Failure Data:

None.

March 23, 1976

NSF-10, Rev. 4

Attachment "(C)"
Page 4 of 4