

MAR 14 1973

Docket No. 50-313

POOR ORIGINAL

Mr. J. D. Phillips
Vice President & Chief Engineer
Arkansas Power & Light Company
Sixth and Pine Streets
Pine Bluff, Arkansas 71601

Dear Mr. Phillips:

We have received your letter of February 28, 1973 asking AEC approval of the use of more recent addenda to ASME Codes affecting valves. It is the position of the AEC Regulatory staff that the requirements of Section III of the ASME Boiler and Pressure Vessel Code, including the Winter 1972 Addenda, provide an acceptable basis for the design, fabrication, and inspection of nuclear components categorized within the appropriate code class.

Sincerely,

Original Signed by
R. C. DeYoung

R. C. DeYoung, Assistant Director
for Pressurized Water Reactors
Directorate of Licensing

cc: Horace Jewell, Esquire
House, Holms & Jewell
1550 Tower Building
Little Rock, Arkansas 72201

DISTRIBUTION
AEC PDR
Local PDR
Docket File
RP Reading
PWR-4 Rdg
RCDeYoung
PWR Branch Chiefs
RWKlecker
RMBernero
EIGoulbourne (2)

OFFICE ▶	PWR-4 <i>RMB</i>	L:C/PWR-4 <i>AS</i>	<i>KXAN</i>	L:AD/PWRs <i>RCDeYoung</i>		
SURNAME ▶	RMBernero:kmf	ASchwencer	JKnight	RCDeYoung		
DATE ▶	3/13/73	3/13/73	3/13/73	3/13/73		

8004210 474 A