

~~MAILED~~  
*To file w/ docket file*  
SEP 7 1971

Docket Nos. 50-313 and 50-308

THIS DOCUMENT CONTAINS  
POOR QUALITY PAGES

Arkansas Power and Light Company  
ATTN: Mr. J. D. Phillips  
Vice President and Chief Engineer  
Sixth and Pine Streets  
Ft. Smith, Arkansas 72901

Gentlemen:

In reviewing the Safety Analysis Reports and Environmental Reports for Arkansas Nuclear One Unit 1 and Unit 2 Facilities, we note inconsistencies among the various documents in reported releases of gaseous effluents. Examples of such inconsistencies are found in comparing Table 3-4 (p.74) of the Environmental Report for Unit 1, Table II.1-I-4 (p.11-11, Vol. II) of the PSAR for Unit 2, Table II-5 (p.11-27 Vol. II) of the PSAR for Unit 1, and lack of specific data in the Environmental Report for Unit 2. Please provide consistent data on releases of gaseous effluents for each facility fully setting forth the assumptions used. For each nuclide released in gaseous effluent please provide maximum design basis values and actual expected values under usual operating conditions for total curies released per year, total curies released during any planned release period, concentrations at the site boundary or in the unrestricted area (Ci/m<sup>3</sup>), and Ci-sec/m<sup>3</sup> for appropriate release periods at the site boundary or in the unrestricted area.

We would appreciate having these data as soon as possible since they are required for the preparation of the environmental statements.

Sincerely yours,

LESTER ROGERS

Distribution:

Public Document Room (2)  
Local PDR: (2)  
Mrs. Robert Keathley, Librarian  
Arkansas River Valley Regional  
Library  
Dardanelle Arkansas 72834  
Docket Files (2)

Lester Rogers, Director  
Division of Radiological and  
Environmental Protection

OFFICE	REP:RPS	REP:ADER	REP:DIR	APB
SURNAME	JL Caplin:seg	<i>JL Caplin:seg</i>	LR Rogers	8004 220 823
DATE	9/2/71	9/3/71	9/7/71	