

Docket No. 50-313

August 26, 1977

DISTRIBUTION

Docket  
NRC PDR  
Local PDR  
ORB #2 Reading  
VStello  
KRGoller  
JMcGough  
TJCarter  
DKDavis  
RMDiggs  
RPSnaider  
DEisenhut  
OI&E (3)  
GELD  
BJones  
TBAbernathy  
JRBuchanan

ACRS (16)

Arkansas Power & Light Company  
ATTN: Mr. William Cavanaugh III  
Executive Director, Generation  
and Construction  
Post Office Box 551  
Little Rock, Arkansas 72203

Gentlemen:

This confirms our telephoned authorization given today, August 26, 1977, for a change in Technical Specifications for the Arkansas Nuclear One - Unit No. 1 facility as requested by your telecopy today. Facility Operating License No. DPR-51 is amended on this date, August 26, 1977, by making the following technical specification changes:

- (1) Delete Paragraph 3.14.2
- (2) Change Paragraph 3.14.3 to 3.14.2 to read as follows:

3.14.2 If the requirements of Specification 3.14.1 cannot be met, the system shall be returned to operable status within 30 days or the reactor shall be placed in the hot shutdown condition within the next 6 hours.

Copies of the license amendment, our evaluation and Notice of Issuance for this Technical Specification will be sent to you when completed.

Sincerely,  
Original signed by:  
Karl R. Goller

Karl R. Goller, Assistant Director  
for Operating Reactors  
Division of Operating Reactors

*Informed  
Don Ruetter  
8/26/77 1700*

cc: See next page

*contacted  
let available IE  
8/26/77 5:05pm  
AKD*

THIS DOCUMENT CONTAINS  
POOR QUALITY PAGES

*60 A13*

OFFICE	DOR:ORB #2	DOR:ORB #2	DOR:AD/OR		
SURNAME	RPSnaider:ro	DKDavis	KRGoller	8004220	JPI
DATE	8/26/77	8/26/77	8/26/77		P

Arkansas Power & Light Company

August 26, 19

cc:  
Phillip K. Lyon, Esquire  
House, Hoims & Jewell  
1550 Tower Building  
Little Rock, Arkansas 72201

Mr. Donald Rueter  
Manager, Licensing  
Arkansas Power & Light Company  
Post Office Box 551  
Little Rock, Arkansas 72201

Arkansas Polytechnic College  
Russellville, Arkansas 72801

OFFICE →					
SURNAME →					
DATE →					