

JAN 10 1975

Docket No. 50-313

Arkansas Power and Light Company  
ATTN: Mr. J. D. Phillips  
Senior Vice President  
Production, Transmission  
and Engineering  
Sixth and Pine Streets  
Pine Bluff, Arkansas 71601

Gentlemen:

DISTRIBUTION:

Docket  
AEC PDR  
Local PDR  
ORB #2 Reading  
Attorney, OGC  
RO (3)  
NDube  
BJones (4)  
RVollmer  
JSaltzman  
RMDiggs  
FDAnderson  
DLZiemann  
SKari  
WOMiller  
BScharf (15)  
TJCarter  
PCollins  
SVarga

Chebron  
RSchemel  
ACRS (16)  
OIS  
HJMcAlduff  
JRBuchanan  
TBAbert

THIS DOCUMENT CONTAINS  
POOR QUALITY PAGES

Our review of your Technical Specifications related to installed filter systems indicates a need for additional Limiting Conditions for Operation (LCO) and Surveillance Requirements (SR). These are required in order to ensure high confidence that the systems will function reliably, when needed, at a degree of efficiency equal to or better than that assumed in the accident analyses.

In order to assist you in the preparation of appropriate revisions, we have prepared model Technical Specifications which include LCO's, SR's and Bases for the following Arkansas Nuclear One - Unit 1 systems:

- 1) Emergency Air Treatment Systems
  - a. Hydrogen Purge Air Treatment System
  - b. Fuel Handling Air Treatment System
  - c. Reactor Building Purge Air Treatment System
  - d. Penetration Room Air Treatment System
- 2) Control Room Air Treatment System

You are requested to submit within 45 days of the date of this letter an application for amendment to your license that would change the Technical Specifications related to installed filter systems so as to be in conformance with the requirements in the enclosed model Technical Specifications.

Sincerely,  
Original signed by  
Dennis L. Ziemann  
Dennis L. Ziemann, Chief  
Operating Reactors Branch #2  
Directorate of Licensing

OF ENCLOSURE:		L:ORB #2	L:ORB #2	
SURNAME:	Model Technical Specifications	FDAnderson/tc	DLZiemann	
cc:	See next page	1/9/75	1/10/75	8004220 893
DATE:				

JAN 10 1975

cc w/enclosures:

Horace Jewell  
Horace, Holms & Jewell  
1550 Tower Building  
Little Rock, Arkansas 72201

Mr. William Cavanaugh, III  
Production Department  
Post Office Box 551  
Little Rock, Arkansas 72203

Arkansas Polytechnic College  
Russellville, Arkansas 72801