

Docket No. 50-313

APR 24 1975

cy of encl
Filed w/Docket 210

DISTRIBUTION

NRC PDR
Local PDR
Docket
ORB #2 Reading
KRGoller
TJCarter
OELD
OI&E (3)
DLZiemann
FDAnderson
RKIngram
JRBuchanan
TBAbernathy
SVarga
ACRS (14)

Arkansas Power & Light Company
ATTN: Mr J.D. Phillips
Senior Vice President
Production, Transmission,
and Engineering
Sixth and Pine Streets
Pine Bluff, Arkansas 71601

Gentlemen:

Our review of recent submittals regarding the reevaluation of emergency core cooling system (ECCS) performance in accordance with 10 CFR 50.46 indicates that certain additional information was required in order for us to complete our evaluation. This letter is to inform you of one part of the evaluations that have been submitted that has required additional information.

In performing the evaluation of single failures of ECCS equipment required by Appendix K to 10 CFR 50, Section I.D.1., the effects of a single failure or operator error that causes any manually-controlled, electrically-operated valve to move to a position that could adversely affect the ECCS must be considered. Therefore, please review your submittals regarding ECCS; and if this consideration has not been specifically reported in the past, your upcoming submittal must address this consideration. Include any proposed plant modifications and changes to the Technical Specifications that might be required to protect against any loss of safety function caused by this type of failure. A copy of Branch Technical Position EICSE 18 from the U.S. Nuclear Regulatory Commission's Standard Review Plan is attached to provide you with guidance.

This request for generic information was approved by CAO under a blanket clearance number E-180225 (80072); this clearance expires July 31, 1977.

Sincerely,

Original signed by
Dennis L. Ziemann
Dennis L. Ziemann, Chief
Operating Reactors Branch #2
Division of Reactor Licensing

THIS DOCUMENT CONTAINS
POOR QUALITY PAGES

Enclosure:
Branch Technical Position EICSE 18

cc w/enclosure: See next page

OFFICE →	RL:ORB #2	RL:ORB #2				
SURNAME →	FDAnderson:tc	DLZiemann			8004250486	
DATE →	4/23/75	4/24/75				

ccs
VRS
p

APR 24 1975

Arkansas Power & Light Company - 2 -

cc w/enclosures:

Horace Jewell
House, Holms & Jewell
1550 Tower Building
Little Rock, Arkansas 72201

Mr. William Cavanaugh, III
Production Department
Post Office Box 551
Little Rock, Arkansas 72203

Arkansas Polytechnic College
Russellville, Arkansas 72801