Docket Nos.: 50-329 and 50-330

Gentlemen:

NOV. 1 9 1975

DISTRIBUTION: NRC PDR L PDR LWR 2-3 Rdg Docket Files VAMoore RHeineman WMcDonald LWR TC's FLD IE (3) SMacKay EGoulbourne TR BC's LWR BC's ACRS (16) TIC

PF bcc: JRBuchanan, ORNL TBAbernathy, DTIE

Consumers Power Company ATTN: Mr. S. H. Howell Vice President 212 West Michigan Avenue Jackson, Michigan 49201

TIC The enclosed comments and requests for information are in response to your letter of September 11, 1975, regarding the implementation of Regulatory Guides at your Midland Plant. These guides deal with materials engineering.

As indicated in our letter of October 15, 1975, your response to this request for information was scheduled for December 8, 1975. Please inform us within seven (7) days after receipt of this letter of your confirmation of this date or the date you will be able to meet.

Please contact us if you have any questions regarding the information requested.

Sincerely,

Original Signed by

A. Schwencer, Chief Light Water Reactors Branch 2-3 Division of Reactor Licensing

Enclosure: Request for Additional Information

cc: See next page

8006110 402

THIS DOCUMENT CONTAINS

POOR QUALITY PAGES

7886/LWB2-3	C-LWR2 3:RL	は生活をやけてん		Contract and	1.1.04
SMackay: TH	ASchwencer				
11/19/75	11/9/75	The second	and the start		2016
	SMacKay: TH	SMackay: m ASchwencer	SMackay: nit ASchwencer	SMackay: nit ASchwencer	SMackay: mil ASchwencer

Consumers Power Company

cc w/encl:

Howard J. Vogel, Esq. Knittle & Vogel 814 Flour Exchange Building 310 Fourth Avenue South Minneapolis, Minnesota 55415

Myron M. Cherry, Esq. Jenner & Block 1 IBM Plaza Chicago, Illinois 60611

Harold F. Reis, Esq. Lowenstein, Newman, Reis & Axelrad 1025 Connecticut Avenue, N.W. Washington, D.C. 20036

Honorable William H. Ward Assistant Attorney General Topeka, Kansas 56601

Irving Like, Esq. Reilly, Like ξ Schneider 200 West Main Street Babylon, New York 11702

James A. Kendall, Esq. 135 N. Saginaw Road Midland, Michigan 48640

OFFICE	
SURNAME >	
DATE	

- 2 -

U. S. GOVERNMENT PRINTING OFFICE: 1974-528-186

the day of a single of

121.0 MATERIALS ENGINEERING BRANCH MATERIALS PERFORMANCE SECTION

- 121.1 With regard to Regulatory Guide 1.2, "Thermal Shock to Reactor Pressure Vessels" (11/2/72), the staff does not consider the material presented to be an exception to this guide. Please confirm your full conformance with Regulatory Guide 1.2.
- 121.2 With regard to Regulatory Guide 1.14, "Reactor Coolant Pump Flywheel Integrity" (10/27/71), please confirm that the design of the reactor coolant pump and flywheel assembly provides access to enable 100% ultrasonic volumetric examination of the flywheels.

121-0

122.0 MATERIALS ENGINEERING BRANCH - MATERIALS APPLICATIONS SECTION

122.1

- Regarding Regulatory Guide 1.31, "Control of Stainless Steel Welding," the degree of compliance with the April 11, 1974, Interim Position of the Guide (i.e., Branch Technical Position MTEB 5-1) is incomplete for the equipment within the B&W scope of supply, for the balance of plant components, and for installation of the NSSS and BOP components. Describe the status of the procurement of the NSSS and BOP austenitic stainless components and the status of the welding installation of the austenitic stainless steel components of the NSSS and the BOP.
- 122.2 Regarding Regulatory Guide 1.34, "Control of Electroslag Weld Properties," the degree of compliance with the Guide is satisfactory for both the B&W scope of supply and the BOP components.
- 122.3 Regarding Regulatory Guide 1.36, "Nonmetallic Thermal Insulation for Austenitic Stainless Steel," the degree of compliance with the Guide is satisfactory for the entire Midland project except for assurance that all of the provisions of Regulatory Position 1 will be complied with. Provide information regarding chloride control during field installation of nonmetallic thermal insulation.
- 122.4 Regarding Regulatory Guide 1.43, "Control of Stainless Steel Weld Cladding of Low-Alloy Steel Components," the degree of compliance with the Guide is incomplete for the B&W scope of supply and for the Midland Construction of BOP components and installation of the NSSS. Describe the status of the procurement and construction of Midland Units 1 and 2 involving stainless steel weld cladding of low-alloy steel components. Position C.1.b of the Regulatory Guide should be complied with for "low-heat-input" as well as "high-heat-input" weld cladding procedures.
- 122.5 Regarding Regulatory Guide 1.44, "Control of the Use of Sensitized Stainless Steel," the degree of compliance with the Guide is satisfactory for the equipment within the B&W scope of supply, except for lack of compliance with Regulatory Guide Position C.3; and is satisfactory for the BOP equipment and for field fabrication and installation, except for lack of compliance with Regulatory Guide Positions C.3 and C.6. Describe the status of the procurement and velding installation of austenitic stainless steel components in Midland 1 and 2.
- 122.6 Regarding Regulatory Guide 1.50, "Control of Preheat Temperature for Welding of Low-Alloy Steel," the degree of compliance with the Guide is satisfactory for the equipment within the B&W scope of supply and is satisfactory for the construction of BOP equipment and the installation of the NSSS, except for lack of compliance with Regulatory Guide Position 1.a. Describe the status of the construction of the BOP equipment and the installation of the NSSS.

Regarding Regulatory Guide 1.65, "Materials and Inspections for Reactor Vessel Closure Studs," the degree of compliance with the Guide is incomplete for the B&W scope of supply. Provide more specific information on fracture toughness, tensile properties, and inspection. Also, provide degree of compliance with Positions C.3 and C.4 of the Guide.

122.8

122.7

Regarding Regulatory Guide 1.66, "Nondestructive Examination of Tubular Products," the degree of compliance with the Guide is incomplete for the equipment within the B&W scope of supply and for the BOP components. Tubular products should be examined either in accordance with all of the positions of the Guide or in accordance with the requirements of the ASME Code, Section III, Summer 1974 Addenda. Describe the status of the procurement of the equipment within the B&W scope of supply and the BOP components.

Regarding Regulatory Guide 1.71, "Welder Qualification for Areas of Limited Accessibility," the degree of compliance with the Guide is satisfactory for Midland 1 and 2.

122-2