	UNITED STATES C ENERGY COMMISSION WASHINGTON, D.C. 20545	MIDLAND :
Docket Nos. 50-329/330	OCT 1 8 1974	1-10134
Consumers Power Company ATTN: Mr. S. H. Howell Vice President 212 West Michigan Avenue Jackson, Michigan 49201	THIS DOCUMENT CONTAINS POOR QUALITY PAGES	- 144 - 144 - 144 - 145 - 145 - 0505,2

Gentlemen:

We have reviewed Section 14.4 of Amendment 25 to your application for construction permits and operating licenses for Units 1 and 2 of your Midland Plant. Section 14.4 of Amendment 25 consists of revisions to the Preliminary Safety Analysis Report that describe your Analysis of High Energy Pipe Ruptures Outside the Reactor Building. Our review of the analysis cannot be completed until revisions to your analysis, applicable to Section 14.4 of Amendment 25, have been submitted which include the following:

- According to Section 14.4.4.3, "For certain postulated breaks, the plant may be placed in hot standby while repairs are made". Provide justification for not bringing the plant to cold shutdown after these high energy line ruptures.
- (2) In the event of a main steam line break, describe the means for automatically isolating the control room from steam.
- (3) Provide a discussion of the effects of critical cracks in high energy lines on essential equipment.
- (4) Discuss the consequences of a rupture of the steam line to the auxiliary feedwater pump turbine coupled with a single active failure of the motor driven auxiliary feedwater pump.

In summary, our review cannot be completed until a high energy analysis for all high energy lines is submitted in the Final Safety Analysis Report for the Midland Plant, Units 1 and 2.



80 06110 516

Sincerely Schweitten

A. Schwencer, Chief Light Water Reactors Branch 2-3 Directorate of Licensing

20'EK(2)

ccs: See next page

OCT 2 5 1974

## Consumers Power Company

ccs: Harold F. Reis, Esquire Newman, Reis, Axelrad 1025 Connecticut Avenue, N. W. Washington, D. C. 20036

- 2 -

:

Honorable William H. Ward Assistant Attorney General Topeka, Kansas 66601

Howard J. Vogel, Esquire Knittle and Vog 1 814 Flour Exchange Building 310 Fourth Avenue South Minneapolis, Minnesota 55415

Irving Like, Esquire Reilly, Like and Schneider 200 West Main Street Babylon, New York 11702

Myron M. Cherry, Esquire Jenner and Block 1 IBM Plaza Chicago, Illinois 60611

James A. Kendall, Esquire 135 N. Saginaw Road Midland, Michigan 48640