



Consumers
Power
Company

Stephen H. Howell
Vice President

General Offices: 1945 West Parnall Road, Jackson, Michigan 49201 • Area Code 517 788-0453

June 8, 1977

REGULATORY DOCKET FILE COPY

Director of Nuclear Reactor Regulation
Attn: Mr Roger Boyd, Director
Division of Project Management
US Nuclear Regulatory Commission
Washington, DC 20555

MIDLAND PROJECT
DOCKET NOS 50-329, 50-330
REACTOR COOLANT SYSTEM
HIGH ENERGY BREAK ANALYSIS CRITERIA
FILE: B3.6 SERIAL: 3773



On May 10 via CPCO Serial 3605 we transmitted a revised Criteria for Postulating Primary System Pipe Breaks for Midland Plant, Units 1 and 2. Along with that submittal we sent a table (Attachment 2) showing the postulated pipe breaks that would occur following the revised criteria.

Since that submittal we have refined the above table so that a separate table is presented for each Midland unit (NSS 12 and NSS 13). These new tables, Attachment 1 and 2 of this letter supersede and replace Attachment 2 of our previous letter (CPCO Serial 3605). The revised criteria as previously submitted, has not changed.

Stephen H. Howell

SHH/JJZ/jbg

8006180671

A

771650211

ATTACHMENT 1
 REACTOR COOLANT SYSTEM PRIMARY PIPING BREAK LOCATIONS FOR A 177 FA PLANT
 CONSUMERS POWER COMPANY - NSS-12 (Unit 2)

BREAKS ARE POSTULATED AT PIPING TERMINAL POINTS AND AT INTERMEDIATE POINTS WHERE THE STRESS EXCEEDS $2.4 S_m$ OR THE CUMULATIVE USAGE FACTOR EXCEEDS 0.1. AT LEAST TWO INTERMEDIATE BREAK LOCATIONS ARE POSTULATED BASED ON STRESS OR CUF ALLOWABLES BEING EXCEEDED OR ON ACTUAL HIGHEST STRESS OR CUF VALUES.

PIPING RUN	MATH MODEL JOINT	STRESS (psi)			CUF	BREAK TYPE		NOTES
		$2.4 S_m(1)$	Eq 12	Eq 13(4)		LONGITUDINAL	GUILLOTINE	
HOT LEG LOOP A	200	46,560	-	-	.010		✓	HL TERMINAL END
	(2)	41,760	-	-	.630		✓	HL TERMINAL END
	179	44,160	4,150	27,230	.004		✓	HL INTERMEDIATE BREAK
	30	44,160	4,000	26,130	.007		✓	HL INTERMEDIATE BREAK
	15	46,560	-	-	.009		✓	HL TERMINAL END
HOT LEG LOOP B	128	41,760	-	-	.491		✓	HL TERMINAL END
	30	44,160	4,000	26,130	.007		✓	HL INTERMEDIATE BREAK
	200	46,560	-	-	.010		✓	HL TERMINAL END
	15	46,560	-	-	.009		✓	HL TERMINAL END
UPPER COLD LEG	196-149	44,880	-	-	.018		✓	UCL TERMINAL END
	191-111	44,880	6,470	29,770	.005		✓	UCL INTERMEDIATE BREAK
	168-37	44,880	26,739	51,774	.042	✓(3)		UCL ELBOW BREAK
	172-47	40,800	-	-	.001		✓	UCL TERMINAL END
LOWER COLD LEG	136-46	40,800	-	-	.002		✓	LCL TERMINAL END
	20-19	44,880	13,410	33,120	.012		✓	LCL INTERMEDIATE BREAK
	118-45	44,880	12,975	50,127	.098	✓(3)		LCL ELBOW BREAK
	3-21	47,280	-	-	.015		✓	LCL TERMINAL END

- NOTES: (1) S_m at $650^{\circ}F$ for Hot Leg and $600^{\circ}F$ for Cold Leg.
 (2) Location of RCS Decay Heat Nozzle.
 (3) Split angle in the primary pipe defined by out-of-plane bending criteria. (See para. 2.2.2.)
 (4) Highest stress value using either X+Y or Y+Z earthquake moments.

ATTACHMENT 2
 REACTOR COOLANT SYSTEM PRIMARY PIPING BREAK LOCATIONS FOR A 177 FA PLANT
 CONSUMERS POWER COMPANY - NSS-13(Unit 1)

BREAKS ARE POSTULATED AT PIPING TERMINAL POINTS AND AT INTERMEDIATE POINTS WHERE THE STRESS EXCEEDS $2.4 S_m$ OR THE CUMULATIVE USAGE FACTOR EXCEEDS 0.1. AT LEAST TWO INTERMEDIATE BREAK LOCATIONS ARE POSTULATED BASED ON STRESS OR CUF ALLOWABLES BEING EXCEEDED OR ON ACTUAL HIGHEST STRESS OR CUF VALUES.

PIPING RUN	MATH MODEL JOINT	STRESS (psi)			CUF	BREAK TYPE		NOTES
		$2.4 S_m(1)$	Eq 12	Eq 13(4)		LONGITUDINAL	GUILLOTINE	
HOT LEG LOOP A	200	46,560	-	-	.010		✓	HL TERMINAL END
	(2)	41,760	-	-	.630		✓	HL TERMINAL END
	128	41,760	-	-	.491		✓	HL TERMINAL END
	30	44,160	4,000	26,130	.007		✓	HL INTERMEDIATE BREAK
	15	46,560	-	-	.009		✓	HL TERMINAL END
HOT LEG LOOP B	200	46,560	-	-	.010		✓	HL TERMINAL END
	179	44,160	4,150	27,230	.004		✓	HL INTERMEDIATE BREAK
	30	44,160	4,000	26,130	.007		✓	HL INTERMEDIATE BREAK
	15	46,560	-	-	.009		✓	HL TERMINAL END
UPPER COLD LEG	196-149	44,880	-	-	.018		✓	UCL TERMINAL END
	191-111	44,880	6,470	29,770	.005		✓	UCL INTERMEDIATE BREAK
	168-37	44,880	26,739	51,774	.042	✓(3)		UCL ELBOW BREAK
	172-47	40,800	-	-	.001		✓	UCL TERMINAL END
LOWER COLD LEG	136-46	40,800	-	-	.002		✓	LCL TERMINAL END
	20-19	44,880	13,410	33,120	.012		✓	LCL INTERMEDIATE BREAK
	118-45	44,880	12,975	50,127	.098	✓(3)		LCL ELBOW BREAK
	3-21	47,280	-	-	.015		✓	LCL TERMINAL END

NOTES: (1) S_m at 650°F for Hot Leg and 600°F for Cold Leg.

(2) Location of RCS Decay Heat Nozzle.

(3) Split angle in the primary pipe defined by out-of-plane bending criteria. (See para. 2.2.2.)

(4) Highest stress value using either X+Y or Y+Z earthquake moments.

NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL

50-3276330
FILE NUMBER

TO: R. BOYD

FROM: CONSUMERS POWER CO.
JACKSON, MICHIGAN
S.D. POWELL

DATE OF DOCUMENT

6/8/77

DATE RECEIVED

6/13/77

LETTER
 ORIGINAL
 COPY

NOTORIZED
 UNCLASSIFIED

PROP

INPUT FORM

NUMBER OF COPIES RECEIVED

1 SIGNED

DESCRIPTION

LTR. TRANS THE FOLLOWING.....

(1P)

DO NOT REMOVE

PLANT NAME: MIDLAND # 1 & 2
SAB

ACKNOWLEDGED

ENCLOSURE

REACTOR COOLANT SYSTEM PRIMARY PIPING BREAK LOC
TION FOR A 177 FA PLANT SURERSENDING AND REPLAC
ING ATTACHMENT 2 OF LTR (CPCO SERIAL 3605).....

(2P)

SAFETY

FOR ACTION/INFORMATION

ENVIRO

ASSIGNED AD:

Vassallo

ASSIGNED AD:

BRANCH CHIEF:

Varga

BRANCH CHIEF:

PROJECT MANAGER:

Powell (2)

PROJECT MANAGER:

LIC. ASST.:

Service

LIC. ASST.:

INTERNAL DISTRIBUTION

RES FILE

SYSTEMS SAFETY

PLANT SYSTEMS

SITE SAFETY &

NRC PDR

HEINEMAN

TEDESCO

ENVIRO ANALYSIS

I & E (2)

SCHROEDER

BENAROYA

DENTON & MILLER

OELD

LAINAS

GOSSICK & STAFF

ENGINEERING

IPPOLITO

ENVIRO TECH.

MIPC

MACCARRY

KIRKWOOD

ERNST

CASE

KNIGHT

OPERATING REACTORS

BALLARD

HANAUER

SHWEI

STELLO

SPANGLER

HARLESS

PAWLICKI

SITE TECH.

PROJECT MANAGEMENT

REACTOR SAFETY

OPERATING TECH.

GAMMILL

BOYD

ROSS

EISENHUT

STAPP

P. COLLINS

NOVAK

SHAO

HULMAN

HOUSTON

ROSZTOCZY

BAER

PETERSON

CHECK

BUTLER

SITE ANALYSIS

MELTZ

GRIMES

VOLLNER

HELFMES

AT & I

BUNCH

SKOVHOLT

SALTZMAN

J. COLLINS

RUTBERG

KRUEGER

EXTERNAL DISTRIBUTION

CONTROL NUMBER

LPDR: *Midland, MICH*

NAT LAB:

BROOKHAVEN NAT LAB

TIC:

REG. VIE

ULRIKSON (ORNL)

NSIC:

LA PDR

ASLB:

CONSULTANTS

ACRS CYS HOLDING/ENT

771650211 MA 4

60