



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20585

TERA

June 16, 1980

THIS DOCUMENT CONTAINS
POOR QUALITY PAGES

Docket No. 80-219

Mr. J. R. Finfrock, Jr.
Vice President - Generation
Jersey Central Power & Light Company
Madison Avenue at Punch Bowl Road
Morristown, New Jersey 07960

Dear Mr. Finfrock:

We have reviewed your submittals dated September 25, 1979 and November 1, 1979 regarding degraded grid voltage and adequacy of station electric distribution system voltages. On March 3, 1980 we telecopied a list of additional information which we required. As the result of a conference call between the NRC staff and its consultant and Mr. George Bush of your staff on April 3, 1980, it was our understanding that Jersey Central Power and Light Company would provide the following information:

REFERENCES: 1. JCP&L Letter dated September 25, 1979
2. JCP&L Letter dated November 1, 1979


1. In Reference 2, the licensee took credit for motors of -15% voltage rating whereas there are some class IE motors of -10% voltage rating. The licensee will provide justification for using -15% as representative rating.
2. Existing gaps and discrepancies in various tables of Reference 1 shall be corrected as discussed and agreed.
3. Equipment terminal voltages shall be provided for the case of starting the largest non-IE motor when all safety loads are operating with other auxiliary loads energized.
4. Statement shall be provided about the qualification of all class IE equipment of lower than 400 V rating for the voltages under all conditions of operations being analyzed.
5. Since each startup transformer is incapable of assuming loads from both trains whereas a tie is possible between the two trains, the licensee will include a Limiting Condition of Operation in the technical specifications that would prohibit closing the tie during operation.

0007030300 P

6. Draft technical specification shall be submitted for our review and will include items indicated in Reference 1 and requirements listed in various tables in our letter of June 3, 1977.
7. Tests to assure the validity of analysis results in Reference 2 shall be performed as discussed. Test method was explained to the licensee and the licensee agreed to submit the results for our review.

Please provide the above requested information within thirty days of the receipt of this letter.

Sincerely,



Gus C. Lainas, Assistant Director
for Safety Assessment
Division of Licensing

June 16, 1980

cc
 J. F. Trowbridge, Esquire
 Shaw, Pittman, Potts and Trowbridge
 1100 M Street, N. W.
 Washington, D. C. 20036

Gene Fisher
 Bureau Chief
 Bureau of Radiation Protection
 380 Scotts Road
 Trenton, New Jersey 08623

EPIC Service Corporation
 ATTN: Mr. E. G. Wallace
 Licensing Manager
 260 Cherry Hill Road
 Parsippany, New Jersey 07054

Mark L. First
 Deputy Attorney General
 State of New Jersey
 Department of Law and Public Safety
 Environmental Protection Section
 36 West State Street
 Trenton, New Jersey 08625

Anthony Z. Roisman
 Natural Resources Defense Council
 217 18th Street, N. W.
 Washington, D. C. 20006

Joseph T. Carroll, Jr.
 Plant Superintendent
 Oyster Creek Nuclear Generating
 Station
 P. O. Box 388
 Forked River, New Jersey 08731

Steven P. Russo, Esquire
 249 Washington Street
 P. O. Box 1060
 Toms River, New Jersey 08753

Director, Technical Assessment
 Division
 Office of Radiation Programs
 (AN-459)
 U. S. Environmental Protection
 Agency
 Crystal Mall #2
 Arlington, Virginia 20460

Joseph A. Ferraro, Jr., Esquire
 Deputy Attorney General
 State of New Jersey
 Department of Law and Public Safety
 1100 Raymond Boulevard
 Newark, New Jersey 07012

U. S. Environmental Protection
 Agency
 Region II Office
 ATTN: EIS COORDINATOR
 26 Federal Plaza
 New York, New York 10007

Ocean County Library
 Brick Township Branch
 101 Chambers Bridge Road
 Brick Town, New Jersey 08723

Major
 Lacey Township
 P. O. Box 475
 Forked River, New Jersey 08731

Commissioner
 Department of Public Utilities
 State of New Jersey
 100 Commerce Street
 Newark, New Jersey 07102