

RECALL NUMBER
PROPOSED RULE

PR-50

THIS DOCUMENT CONTAINS
POOR QUALITY PAGES

Marvin I. Lewis
6504 Bradford Ter.
Phila. PA 19149

(45 FR 36082)

5.31.80.

Comments on PROPOSED AMENDMENTS

Federal Register Notice May 29, 1980
"FIRE PROTECTION" Part 50.



1. These amendments are in response to a fire at Browns Ferry 5 years ago. "Justice delayed is justice denied." The minimum response to Brown's Ferry should have been to close all nukes until these amendments were passed and implemented.
2. Why only 2 hours of fire fighting water when Browns Ferry was well over 2 hours of fire fighting? This requirement is only $\frac{2}{11} \times 100 = 18\%$ of what experience at Browns Ferry has shown to be needed.
3. "Special protective features" must include properly designed + separated "trays." Cabling must be suspended above floor of tray and holes must be cut in floor of tray.
4. No lines containing flammable liquids (hydraulic fluid, solvent, pneumatic oil-based fluid) may share tunnels with electrical cables.

ACKNOWLEDGED by acc'd.. 6/4/80.. mdw..

8007030349 front on P.2.

Marvin I. Lewis

1-41, pt. 50

2.

5. Therefore brigade "shall have no other duties but fire fighting. They may not be janitors or other personnel. They must be well-trained in fire fighting and first aid.

Mervin J. Lewis

P.S. These are limited comments and they do not imply that there are no other problems with these amendments.