

**Florida
Power**
CORPORATION

July 22, 1980

File: 3-0-3-a-3

Director
Office of Nuclear Reactor Regulation
Division of Operating Reactors
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Subject: Crystal River Unit 3
Docket No. 50-302
Operating License No. DPR-72
Technical Specification Change Request No. 61

Dear Sir:

Enclosed are three (3) originals and forty (40) copies of revised proposed pages to the Crystal River Unit 3 Technical Specifications. These revised pages correct a simplifying assumption made during Babcock & Wilcox re-analysis of Cycle 3, the results of which were transmitted to you in R.M. Bright's letter of April 30, 1980. The original Cycle 3 Reload Report (BAW-1607) was based on a thermal power level of 2544 MWt and included reactor coolant pump power monitors. These assumptions allowed the utilization of a flux/flow ratio of 1.070. A revised analysis was based on a ratio 1.04 (1.044 rounded off). The reduction and operating flexibility resulting from this round off is unnecessary and undesirable.

It is, therefore, requested that Technical Specification Change Request No. 61 be modified to include the attached revised pages.

Also included is one (1) signed copy of the Certificate of Service for revision to Technical Specification Change Request No. 61 to the Chief Executive of Citrus County, Florida.

Sincerely,

FLORIDA POWER CORPORATION

P. Y. Baynard


P. Y. Baynard
Manager
Nuclear Support Services

Baynard(Td)D3-1


STATE OF FLORIDA

COUNTY OF PINELLAS

P. Y. Baynard states that she is the Manager, Nuclear Support Services Department of Florida Power Corporation; that she is authorized on the part of said company to sign and file with the Nuclear Regulatory Commission the information attached hereto; and that all such statements made and matters set forth therein are true and correct to the best of her knowledge, information and belief.


P. Y. Baynard

Subscribed and sworn to before me, a Notary Public in and for the State and County above named, this 22nd day of July, 1980.


Notary Public

Notary Public, State of Florida at Large,

My Commission Expires: June 8, 1984

PYB/MAHNotary(DN-98)

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

IN THE MATTER OF)

FLORIDA POWER CORPORATION)

DOCKET NO. 50-302

CERTIFICATE OF SERVICE

P. Y. Baynard deposes and says that the following has been served on the Chief Executive of Citrus County, Florida by deposit in the United States mail, addressed as follows:

Chairman, Board of County
Commissioners of Citrus County
Citrus County Courthouse
Inverness, Florida 32650

An original copy of the revision to Technical Specification Change Request, No. 61, requesting amendment to Appendix A of Operating License No. DPR-72.

FLORIDA POWER CORPORATION

Patsy G. Baynard
P. Y. Baynard
Manager
Nuclear Support Services

SWORN TO AND SUBSCRIBED BEFORE ME THIS 22nd DAY OF JULY, 1980.

Margaret A. Wensford
Notary Public

Notary Public State of Florida at Large
My Commission expires: June 8, 1984

(NOTARIAL SEAL)

(Cert.Serv.D12)