

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (1)

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	N	C	B	E	P	2	0	0	-	0	0	0	0	0	0	0	0	0	3	4	1	1	1	1	4	5																																																										
7	8	9	LICENSEE CODE					14	15	LICENSE NUMBER								25	26	LICENSE TYPE					30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90

0	1	L	0	5	0	-	0	3	2	4	7	C	7	0	1	8	0	0	7	1	7	8	0	9	
7	8	REPORT SOURCE		60	61	DOCKET NUMBER					68	69	EVENT DATE					74	75	REPORT DATE					80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | During the performance of High Drywell Pressure Channel Calibration and Functional

0 3 | Test, P.T.1.1.3PC, I&C Technicians found pressure switch, 2-C72-PS-N002B, model number

0 4 | 12N-AA4-X10TT, actuating out of tolerance. The switch actuated at 56.3 inches of

0 5 | water applied while the reportable limit is greater than 55.36 inches of water applied.

0 6 | The event did not affect the health or safety of the public.

0 8 | _____ Technical Specifications 3.3.2, 6.9.1.9a _____ 80

0	9	S	D	E	G	I	N	S	T	R	U	S	Z			
7	8	SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE				COMP. SUBCODE		VALVE SUBCODE		
17	LER/RO REPORT NUMBER		EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.					
33	ACTION TAKEN		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | Instrument drift caused the pressure switch to be out of tolerance. The switch was

1 1 | recalibrated and P.T.1.1.3PC was completed satisfactory. A review of the past 2-year

1 2 | history of this model pressure switch showed no unusual or reportable charac-

1 3 | teristics; therefore, this is considered an isolated event with no further action

1 4 | required. These switches are functionally tested monthly and calibrated every 3 months.

1	5	H	0	0	0	NA	B	Periodic Test			
7	8	FACILITY STATUS		% POWER		OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION	

1	6	Z	NA	NA	NA		
7	8	ACTIVITY CONTENT		AMOUNT OF ACTIVITY		LOCATION OF RELEASE	

1	7	0	0	0	Z	NA
7	8	PERSONNEL EXPOSURES		DESCRIPTION		

1	8	0	0	0	NA
7	8	PERSONNEL INJURIES		DESCRIPTION	

1	9	Z	NA
7	8	LOSS OF OR DAMAGE TO FACILITY	

2	0	N	NA
7	8	PUBLICITY ISSUED	