



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION II
101 MARIETTA ST., N.W., SUITE 3100
ATLANTA, GEORGIA 30303

JUN 13 1980


In Reply Refer To:
RII:JPO
50-424, 50-425

Georgia Power Company
Attn: J. H. Miller, Jr.
Executive Vice President
270 Peachtree Street, N.W.
Atlanta, Georgia 30303

Gentlemen:

This Information Notice is being forwarded to you for information.
No written response to this Information Notice is required. If you have
any questions related to the subject, please contact this office.

Sincerely,


James P. O'Reilly
Director

Enclosures:

1. IE Information Notice
No. 80-28
2. List of Recently Issued
Information Notices

8007250375

Q

JUN 13 1980

Georgia Power Company

-2-

cc w/encl:

K. M. Gillespie
Construction Project Manager
Post Office Box 282
Waynesboro, Georgia 30830

E. D. Groover
QA Site Supervisor
Post Office Box 282
Waynesboro, Georgia 30830

UNITED STATES
NUCLEAR REGULATORY COMMISSION
OFFICE OF INSPECTION AND ENFORCEMENT
WASHINGTON, D.C. 20555

SSINS No.: 6835
Accession No.:
8005050063

June 13, 1980

IE Information Notice No. 80-28

PROMPT REPORTING OF INFORMATION IN ACCORDANCE WITH 10 CFR 50.55(e)

The recently implemented expansion of the NRC Resident Inspection Program at nuclear power plants and fuel facilities, has led to some misunderstandings regarding the required reporting of information to the NRC. In order to clarify this matter, the following is provided for your information.

Some licensees have been making the 24 hour reports required by 10 CFR 50.55(e)(2) orally to NRC resident inspectors. This does not satisfy the intent of the regulation. Adherence by all licensees to the explicit requirements of the regulation provides for each Regional Office to be a single focal point for reporting, and minimizes the possibility of inadvertent oversight. While we continue to enlist your cooperation in fully informing our resident inspectors, where appropriate, or any other NRC inspector who may be at your facility at such a time, such informational exchanges do not satisfy the reporting requirements of 10 CFR 50.55(e)(2).

Your cooperation in assuring that the appropriate members of your staff are fully aware of this information will be appreciated.

No written response to this information notice is required. If you require additional information regarding this matter contact the Director of the appropriate NRC Regional Office.

RECENTLY ISSUED
IE INFORMATION NOTICES

Information Notice No.	Subject	Date Issued	Issued To
80-28	Prompt Reporting of Information in Accordance with 10 CFR 55.55(e)	6/13/80	All holders of nuclear power reactor construction permits
80-27	Degradation of Reactor Coolant Pump Studs	6/11/80	All Pressurized Water Reactor Facilities holding power reactor OLs or CPs
80-26	Evaluation of Contractor QA Programs	6/10/80	All Part 50 Licensees
80-25	Transportation of Pyrophoric Uranium	5/30/80	Material Licensee in Priority/Categories II-A, II-D, III-I and IV-DI; Agreement State Licensees in equivalent categories
80-24	Low Level Radioactive Waste Burial Criteria	5/30/80	All NRC and Agreement State Licensees
80-23	Loss of Suction to Emergency Feedwater Pumps	5/29/80	All power reactor facilities with an OL or CP
80-22	Breakdown In Contamination Control Programs	5/28/80	All power reactor OLs and near term CPs
80-21	Anchorage and Support of Safety-Related Electrical Equipment	5/16/80	All power reactor facilities with an OL or CP
80-20	Loss of Decay Heat Removal Capability at Davis-Besse Unit 1 While in a Refueling Mode	5/8/80	All light water reactor facilities holding power reactor OLs or CPs
80-19	NIOSH Recall of Recirculating-Mode (Closed-Circuit) Self-Contained Breathing Apparatus (Rebreathers)	5/6/80	All holders of a power reactor OL, Research Reactor License, Fuel Cycle Facility License and Priority I Material License