



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
REGION II  
101 MARIETTA ST., N.W., SUITE 3100  
ATLANTA, GEORGIA 30303

JUN 13 1980


In Reply Refer To:  
RII:JPO  
50-416, 50-417

Mississippi Power and Light Company  
Attn: N. L. Stampley  
Vice President of Production  
P. O. Box 1640  
Jackson, Mississippi 39205

Gentlemen:

This Information Notice is being forwarded to you for information.  
No written response to this Information Notice is required. If you have  
any questions related to the subject, please contact this office.

Sincerely,

  
James P. O'Reilly  
Director

Enclosures:

1. IE Information Notice  
No. 80-28
2. List of Recently Issued  
Information Notices

8007250377

Q

JUN 13 1980

Mississippi Power and  
Light Company

-2-

cc w/encl:  
C. K. McCoy  
Plant Manager  
Post Office Box 756  
Port Gibson, Mississippi 39150

UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
OFFICE OF INSPECTION AND ENFORCEMENT  
WASHINGTON, D.C. 20555

SSINS No.: 6835  
Accession No.:  
8005050063

June 13, 1980

IE Information Notice No. 80-28

PROMPT REPORTING OF INFORMATION IN ACCORDANCE WITH 10 CFR 50.55(e)

The recently implemented expansion of the NRC Resident Inspection Program at nuclear power plants and fuel facilities, has led to some misunderstandings regarding the required reporting of information to the NRC. In order to clarify this matter, the following is provided for your information.

Some licensees have been making the 24 hour reports required by 10 CFR 50.55(e)(2) orally to NRC resident inspectors. This does not satisfy the intent of the regulation. Adherence by all licensees to the explicit requirements of the regulation provides for each Regional Office to be a single focal point for reporting, and minimizes the possibility of inadvertent oversight. While we continue to enlist your cooperation in fully informing our resident inspectors, where appropriate, or any other NRC inspector who may be at your facility at such a time, such informational exchanges do not satisfy the reporting requirements of 10 CFR 50.55(e)(2).

Your cooperation in assuring that the appropriate members of your staff are fully aware of this information will be appreciated.

No written response to this information notice is required. If you require additional information regarding this matter contact the Director of the appropriate NRC Regional Office.

IE Information Notice No. 80-28  
June 13, 1980

Enclosure

RECENTLY ISSUED  
IE INFORMATION NOTICES

| Information Notice No. | Subject  | Date Issued | Issued To  |
|------------------------|--|-------------|--|
| 80-28                  | Prompt Reporting of Information in Accordance with 10 CFR 55.55(e)                                   | 6/13/80     | All holders of nuclear power reactor construction permits  |
| 80-27                  | Degradation of Reactor Coolant Pump Studs  | 6/11/80     | All Pressurized Water Reactor Facilities holding power reactor OLs or CPs  |
| 80-26                  | Evaluation of Contractor QA Programs   | 6/10/80     | All Part 50 Licensees  |
| 80-25                  | Transportation of Pyrophoric Uranium   | 5/30/80     | Material Licensee in Priority/Categories II-A, II-D, III-I and IV-DI; Agreement State Licensees in equivalent categories |
| 80-24                  | Low Level Radioactive Waste Burial Criteria  | 5/30/80     | All NRC and Agreement State Licensees  |
| 80-23                  | Loss of Suction to to Emergency Feedwater Pumps  | 5/29/80     | All power reactor facilities with an OL or CP  |
| 80-22                  | Breakdown In Contamination Control Programs  | 5/28/80     | All power reactor OLs and near term CPs  |
| 80-21                  | Anchorage and Support of Safety-Related Electrical Equipment   | 5/16/80     | All power reactor facilities with an OL or CP  |
| 80-20                  | Loss of Decay Heat Removal Capability at Davis-Besse Unit 1 While in a Refueling Mode                | 5/8/80      | All light water reactor facilities holding power reactor OLs or CPs  |
| 80-19                  | NIOSH Recall of Recirculating-Mode (Closed-Circuit) Self-Contained Breathing Apparatus (Rebreathers) | 5/6/80      | All holders of a power reactor OL, Research Reactor License, Fuel Cycle Facility License and Priority I Material License |