

P&R-17



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION IV
611 RYAN PLAZA DRIVE, SUITE 1000
ARLINGTON, TEXAS 76012

23 JUN 1980

Docket No. 99900340/80-01

Yarway Corporation
Attn: Mr. F. S. Myers
Vice President, Product Reliability
Blue Bell, PA 19422

Gentlemen:

Our letter of June 17, 1980, that was in response to your letter of May 23, 1980, did not correctly relate to the fact that only item (f) (magnetic field strength) of Article 732 of Section V of the ASME code should have been identified as a deviation. We have corrected our records to accurately reflect this matter.

We have no further questions at this time and will review your corrective action of item (f) during our next inspection.

Sincerely,

A. G. Whitehall for
Udis Potapovs, Chief
Vendor Inspection Branch