CENTRAL FLUES

NORTHEAST UTILITIES

P.O. BOX 270 HARTFORD, CONNECTICUT 06101 (203) 666-6911

July 8, 1980

Docket No. 50-245 A01075

Mr. Boyce H. Grier, Director Region I Office of Inspection and Enforcement U. S. Nuclear Regulatory Commission 631 Park Avenue King of Prussia, PA 19406

Reference: (1) B. H. Grier letter to W. G. Counsil dated July 3, 1980 transmitting I&E Bulletin No. 80-17.

Gentlemen:

Millstone Nuclear Power Station, Unit No. 1 I&E Bulletin No. 80-17

In Reference (1), the NRC Staff requested that Northeast Nuclear Energy Company (NNECO) perform surveillance tests at Millstone Unit No. 1 to verify that there is no significant amount of water in the Scram Discharge Volume (SDV) and associated piping and that the SDV vent valves are operable and vent system is free of obstruction.

In response to Item 1 of Reference (1), NNECO has satisfactorily completed surveillance testing at Millstone Unit No. 1 and has verified that there is no significant amount of water in the Scram Discharge Volume (SDV) and associated piping and that the SDV vent valves are operable and vent system is free of obstruction. Additionally, this surveillance test is being performed on a daily basis to meet the requirements of Item 5 of Reference (1).

We trust you find this information satisfactorily dispositions the Reference (1) concerns.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY

W. G. Counsil Senior Vice President

8008910267

STATE OF CONNECTICUT )
COUNTY OF HARTFORD )

ss. Berlin

July 8, 1980

Then personally appeared before me W. G. Counsil, who being duly sworn, did state that he is Senior Vice President of Northeast Nuclear Energy Company, a Licensee herein, that he is authorized to execute and file the foregoing information in the name and on behalf of the Licensees herein and that the statements contained in said information are true and correct to the best of his knowledge and belief.

ila m. Ontes Notary Public

My Commission Expires March 31, 1981