

**NORTHEAST UTILITIES**



THE CONNECTICUT LIGHT AND POWER COMPANY  
THE HARTFORD ELECTRIC LIGHT COMPANY  
WESTERN MASSACHUSETTS ELECTRIC COMPANY  
HOLYOKE WATER POWER COMPANY  
NORTHEAST UTILITIES SERVICE COMPANY  
NORTHEAST NUCLEAR ENERGY COMPANY

72c  
P.O. BOX 270  
HARTFORD, CONNECTICUT 06101  
(203) 666-6911

July 11, 1980

Docket Nos. 50-213  
50-245  
50-336  
A00956

Mr. Boyce H. Grier, Director  
Region I  
Office of Inspection and Enforcement  
U. S. Nuclear Regulatory Commission  
631 Park Avenue  
King of Prussia, PA 19406

Reference: (1) B. H. Grier letter to W. G. Council dated April 4, 1980,  
transmitting I&E Bulletin No. 79-03A.

Gentlemen:

Haddam Neck Plant  
Millstone Nuclear Power Station, Unit Nos. 1 and 2  
I&E Bulletin No. 79-03A

In Reference (1), the NRC Staff requested that Connecticut Yankee Atomic Power Company (CYAPCO) and Northeast Nuclear Energy Company (NNECO) determine whether SA-312 or A-312, Type 300 Series fusion welded pipe is in use or planned for use in safety-related systems subject to design stresses greater than 85% of the Code Allowable stresses.

In response to Item 1 of Reference (1), CYAPCO and NNECO provide the following information for the Haddam Neck Plant and Millstone Unit Nos. 1 and 2.

Haddam Neck Plant

CYAPCO has reviewed the safety-related piping systems at the Haddam Neck Plant and has determined that there is no SA-312 or A-312 welded pipe in use at greater than 85% of the Code Allowable stress.

8008010 280

Millstone Unit No. 1

NNECO has reviewed the piping systems at Millstone Unit No. 1 and has determined that there is no welded SA-312 or A-312 pipe in use at Millstone Unit No. 1.

Millstone Unit No. 2


NNECO has reviewed the safety-related piping systems at Millstone Unit No. 2 and has determined that there is no SA-312 or A-312 welded pipe in use at greater than 85% of the Code Allowable stress.

As there is no SA-312 or A-312 welded pipe subject to design stresses greater than 85% of the Code Allowable stresses at the Haddam Neck Plant, Millstone Unit No. 1, or Millstone Unit No. 2, Item 2 of Reference (1) is not applicable.

We trust you find this information satisfactory dispositions the Reference (1) concerns. No further action is planned.

Very truly yours,

CONNECTICUT YANKEE ATOMIC POWER COMPANY  
NORTHEAST NUCLEAR ENERGY COMPANY



W. G. Council  
Senior Vice President