



Docket No. 50-334

UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION I
631 PARK AVENUE
KING OF PRUSSIA, PENNSYLVANIA 19406

JUL 14 1980

Duquesne Light Company
ATTN: Mr. C. N. Dunn
Vice President
Operations Division
435 Sixth Avenue
Pittsburgh, Pennsylvania 15219

Gentlemen:

Subject: Inspection 50-334/80-03

This refers to your letter dated July 2, 1980, in response to our letter dated April 2, 1980.

Thank you for informing us of the corrective and preventive actions documented in your letter. These actions will be examined during a subsequent inspection of your licensed program.

Your cooperation with us is appreciated.

Sincerely,

Robert T. Carlson, Chief
Reactor Construction and
Engineering Support Branch

cc:
F. Bissert, Technical Assistant Nuclear
R. Washabaugh, QA Manager
J. Werling, Station Superintendent
G. Moore, General Superintendent, Power Stations Department
J. J. Carey, Director of Nuclear Operations
R. Martin, Nuclear Engineer
J. Sieber, Superintendent of Licensing and Compliance, BVPS

8008060001



Duquesne Light

435 Sixth Avenue
Pittsburgh, Pa.
15219

(412) 456-6000

July 2, 1980

United States Nuclear Regulatory Commission
Office of Inspection and Enforcement
Attn: Robert T. Carlson, Chief
Reactor Construction and Engineering Support Branch
Region I
631 Park Avenue
King of Prussia, Pennsylvania 19406

Reference: Beaver Valley Power Station, Unit No. 1
Docket No. 50-334, License No. DPR-66
IE Inspection No. 80-03

Dear Mr. Carlson:

In response to your letter dated April 2, 1980, forwarding the subject inspection report, our letter dated April 28, 1980, was submitted in accordance with 10CFR2.201. The reply addressed the actions taken as a result of the noted noncompliance - the failure to follow procedures and perform station housekeeping tours.

Following discussions with the NRC Resident Inspector concerning our reply, the following actions are being taken:

1. The option of the Station Superintendent to waive the formal housekeeping tours will be deleted from the housekeeping procedure.
2. During heavy construction activities, Construction Safety Inspectors will be required to conduct housekeeping tours in accordance with Chapter 1, Section J, of the Beaver Valley Power Station Maintenance Manual to supplement the required facilities inspection tours. Problem areas that are identified on the construction tour reports will be reviewed and investigated for resolution.
3. Dependent upon the magnitude of maintenance and/or construction activities, housekeeping tour frequencies will be adjusted as plant conditions dictate.


Dupe of

8007080278

4. The Beaver Valley Power Station Fire Protection Plan is written in accordance with Regulatory Guide 1.120, "Fire Protection Guidelines For Nuclear Power Plants," which references Regulatory Guide 1.39 for housekeeping requirements. The Beaver Valley Power Station Maintenance Manual, Chapter 1, Section J - Housekeeping, is being revised to reflect the requirements of Regulatory Guide 1.39, "Housekeeping Requirements For Water-Cooled Nuclear Power Plants" and ANSI N45.2.3, "Housekeeping During the Construction Phase of Nuclear Power Plants," which states, "Periodic inspection and examination of the work areas and the construction practices shall be performed at scheduled intervals to assure adequacy of cleanness and housekeeping practices."
5. The above noted revisions to the Maintenance Manual will be issued by July 7, 1980.

If you have any questions concerning this response, please contact my office.

Very truly yours,


C. N. Dunn
Vice President, Operations

cc: Mr. D. A. Beckman, Resident Inspector
U.S. Nuclear Regulatory Commission
Beaver Valley Power Station
Shippingport, Pennsylvania 15077

U.S. Nuclear Regulatory Commission
c/o Document Management Branch
Washington, D.C. 20555