



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555  
July 25, 1980

TERA

Docket No. 50-285

Mr. W. C. Jones  
Division Manager, Production  
Operations  
Omaha Public Power District  
1623 Harney Street  
Omaha, Nebraska 68102


Dear Mr. Jones:

The Commission has issued the enclosed Amendment No. 49 to Facility Operating License No. DPR-40 for the Fort Calhoun Station, Unit No. 1. This amendment consists of changes to the Technical Specifications in response to your applications transmitted by letters dated July 5, 1979 and May 12, 1980, as supplemented by letter dated May 14, 1980.

The amendment changes the Technical Specifications to remove the requirement to cycle certain non-redundant pumps and valves and adds requirements for ensuring the availability of auxiliary feedwater.

Copies of the Safety Evaluation and Notice of Issuance are also enclosed.

Sincerely,

  
Robert A. Clark, Chief  
Operating Reactors Branch #3  
Division of Licensing

Enclosures:

1. Amendment No. 49
2. Safety Evaluation
3. Notice

cc w/enclosures:  
See next page

8008060138

P

Omaha Public Power District

cc:

Margaret R. A. Paradis  
LeBoeuf, Lamb, Leiby & MacRae  
1333 New Hampshire Avenue, NW.  
Washington, D. C. 20036

Mr. Emmett Rogert  
Chairman, Washington County  
Board of Supervisors  
Blair, Nebraska 68023

Omaha Public Power District  
ATTN: Mr. Spencer Stevens  
Plant Manager  
Fort Calhoun Plant  
1623 Harney Street  
Omaha, Nebraska 68102

Director, Technical Assessment  
Division  
Office of Radiation Programs  
(AW-459)  
U. S. Environmental Protection Agency  
Crystal Mall #2  
Arlington, Virginia 20460

U. S. Environmental Protection Agency  
Region VII  
ATTN: EIS COORDINATOR  
1735 Baltimore Street  
Kansas City, Missouri 64108

Mr. Frank Gibson  
W. Dale Clark Library  
215 South 15th Street  
Omaha, Nebraska 68102

cc w/enclosure(s) & incoming dtd: 1/7/5/79 & 5/14/80  
Director, Nebraska Department of  
Environmental Control  
Post Office Box 94877, State House Station  
Lincoln, Nebraska 68509

Alan H. Kirshen, Esq.  
Associate Professor of Law  
Creighton University  
School of Law  
2500 California Street  
Omaha, Nebraska 68178

Mr. Charles B. Brinkman  
Manager - Washington Nuclear  
Operations  
C-E Power Systems  
Combustion Engineering, Inc.  
4853 Cordell Ave., Suite A-1  
Bethesda, Maryland 20014