

TIC  
Central

JUL 25 1980

Docket No. 50-245

DISTRIBUTION:

Docket	NSIC
NRC PDR	TERA
Local PDR	ACRS (16)
ORB#5 Reading	JHeltemes
NRR Reading	
DEisenhut	
RPurple	
TNovak	
Tedesco	
GLainas	
JOIshinski	
OELD	
OI&E (3)	
DCrutchfield	
JShea	
HSmith	
TCheng	
DAIison	

Mr. W. G. Council  
 Nuclear Engineering and Operations  
 Northeast Nuclear Energy Company  
 Post Office Box 270  
 Hartford, Connecticut 06101

Dear Mr. Council:

SUBJECT: SEP TOPIC III-6 (SEISMIC DBE REVIEW)

We are continuing our review of the Material on piping systems submitted by your letter dated May 30, 1980. We have found that the information described below is required to continue our evaluation of the Millstone Unit No. 1 piping systems. This request was discussed with your representative (R. McGuinness) by telephone on July 21, 1980.

1. Diesel-Oil and Air Lines:
  - a. Design information (design criteria, data, isometric drawings, etc.) for the underground lines to the oil day tank and the compressed air lines.
  - b. Support details showing configuration, original load, etc.
2. Isolation Condenser Condensate Transfer Line:
  - a. Valve data (weight, e.g., length, etc.), support details, penetration location, etc.
  - b. Isometric drawings are not clear, e.g. dimensions, configuration of adjoining piping, etc.
3. Shutdown Cooling Line: Valve data (weight, e.g., length, etc.) and support details.
4. Original design criteria and data for the three lines above plus the feedwater system.

Your response is requested within 30 days of your receipt of this letter.

Sincerely,

ORB#5:DL/C  
 DCrutchfield  
 7/24/80

Original signed by:

OFFICE	SEP:DL	SEP:DL	ORB#5/DL	Dennis M. Crutchfield, Chief	ORB#5:DL/PI
SURNAME	TCheng:dk	DAIison	HSmith	Operating Reactors Branch #5	JShea
DATE	7/23/80	7/24/80	7/24/80	Division of Licensing	7/24/80

cc: See next page

0008060439



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

JUL 25 1980

Docket No. 50-245

Mr. W. G. Council  
Nuclear Engineering and Operations  
Northeast Nuclear Energy Company  
Post Office Box 270  
Hartford, Connecticut 06101

Dear Mr. Council:

SUBJECT: SEP TOPIC III-6 (SEISMIC DBE REVIEW)

We are continuing our review of the material on piping systems submitted by your letter dated May 30, 1980. We have found that the information described below is required to continue our evaluation of the Millstone Unit No. 1 piping systems. This request was discussed with your representative (R. McGuinness) by telephone on July 21, 1980.

1. Diesel Oil and Air Lines:

- a. Design information (design criteria, data, isometric drawings, etc.) for the underground lines to the oil day tank and the compressed air lines.
- b. Support details showing configuration, original load, etc.

2. Isolation Condenser Condensate Transfer Line:


- a. Valve data (weight, e.g., length, etc.), support details, penetration location, etc.
- b. Isometric drawings are not clear, e.g. dimensions, configuration of adjoining piping, etc.

3. Shutdown Cooling Line: Valve data (weight, e.g., length, etc.) and support details.

4. Original design criteria and data for the three lines above plus the feedwater system.

Your response is requested within 30 days of your receipt of this letter.

Sincerely,

  
Dennis M. Crutchfield, Chief  
Operating Reactors Branch #5  
Division of Licensing

cc: See next page

Mr. W. G. Council

cc

William H. Cuddy, Esquire  
Day, Berry & Howard  
Counselors at Law  
One Constitution Plaza  
Hartford, Connecticut 06103

Natural Resources Defense Council  
917 15th Street, N. W.  
Washington, D. C. 20005

Northeast Nuclear Energy Company  
ATTN: Superintendent  
Millstone Plant  
P. O. Box 128  
Waterford, Connecticut 06385

Mr. James R. Himmelwright  
Northeast Utilities Service Company  
P. O. Box 270  
Hartford, Connecticut 06101

Resident Inspector  
c/o U. S. NRC  
P. O. Box Drawer KK  
Niantic, Connecticut 06357

Waterford Public Library  
Rope Ferry Road, Route 156  
Waterford, Connecticut 06385

First Selectman of the Town  
of Waterford  
Hall of Records  
200 Boston Post Road  
Waterford, Connecticut 06385

John F. Opeka  
Systems Superintendent  
Northeast Utilities Service Company  
P. O. Box 270  
Hartford, Connecticut 06101

Connecticut Energy Agency  
ATTN: Assistant Director  
Research and Policy  
Development  
Department of Planning and  
Energy Policy  
20 Grand Street  
Hartford, Connecticut 06106

Director, Technical Assessment  
Division  
Office of Radiation Programs  
(AW-459)  
U. S. Environmental Protection  
Agency  
Crystal Mall #2  
Arlington, Virginia 20460

U. S. Environmental Protection  
Agency  
Region I Office  
ATTN: EIS COORDINATOR  
JFK Federal Building  
Boston, Massachusetts 02203