

APPENDIX A

NOTICE OF VIOLATION

Portland General Electric Company  
Trojan Nuclear Plant

Docket No. 50-344  
License No. NPF-1

During an NRC inspection conducted from July 30 through September 9, 1989, a violation of NRC requirements was identified. In accordance with the "General Statement of Policy and Procedure for NRC Enforcement Actions," 10 CFR Part 2, Appendix C (1989), the violation is listed below:

Trojan Technical Specification Surveillance Requirement 4.1.3.1.1 states "The position of each rod shall be determined to be within the group demand limit by verifying the individual rod positions at least once per 12 hours except during time intervals when the Rod Position Deviation Monitor is inoperable, then verify the group positions at least once per four hours."

Contrary to the above, from July 16, 1989, through August 1, 1989, while the reactor was in Mode 1 or Mode 2 with the Rod Position Deviation Monitor inoperable, the position of each rod was not determined to be within the group demand limit by verifying the individual rod positions at least once per four hours; rather the rod positions were verified once every twelve hours.

This is a Severity Level IV violation (Supplement I).

Pursuant to the provisions of 10 CFR 2.201, Portland General Electric Company is hereby required to submit a written statement of explanation to the U.S. Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington, DC 20555 with a copy to the Regional Administrator, Region V, and a copy to the NRC Senior Resident Inspector, Trojan, within 30 days of the date of the letter transmitting this Notice. This reply should be clearly marked as a "Reply to a Notice of Violation" and should include for each violation: (1) the reason for the violation if admitted, (2) the corrective steps that have been taken and the results achieved, (3) the corrective steps that will be taken to avoid further violations, and (4) the date when full compliance will be achieved. If an adequate reply is not received within the time specified in this Notice, an order may be issued to show cause why the license should not be modified, suspended, or revoked or why such other action as may be proper should not be taken. Consideration may be given to extending the response time for good cause shown.

FOR THE NUCLEAR REGULATORY COMMISSION

*A. E. Chaffee*

*for* A. E. Chaffee, Acting Chief  
Reactor Projects Branch

Dated at Walnut Creek, California  
this 29<sup>th</sup> day of September, 1989