

## PLANT SYSTEMS

### MAIN STEAM LINE ISOLATION VALVES

#### LIMITING CONDITION FOR OPERATION

---

3.7.1.5 Each main steam line isolation valve (MSIV) shall be OPERABLE.

APPLICABILITY: MODES 1, 2, 3, and 4.

#### ACTION:

##### MODE 1:

With one MSIV inoperable but open, POWER OPERATION may continue provided the inoperable valve is restored to OPERABLE status within 4 hours; otherwise be in HOT STANDBY within the next 6 hours and in HOT SHUTDOWN within the following 6 hours.

##### MODES 2, 3, and 4:

With one MSIV inoperable, subsequent operation in MODE 2 or 3 or 4 may proceed provided the isolation valve is maintained closed. Otherwise, be in HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

#### SURVEILLANCE REQUIREMENTS

---

4.7.1.5.1 Each MSIV shall be demonstrated OPERABLE by verifying full closure within 5 seconds in Modes 1, 2, and 3 when tested pursuant to Specification 4.0.5. The provisions of Specification 4.0.4 are not applicable for entry into MODE 3.

4.7.1.5.2 Each MSIV shall be demonstrated OPERABLE by verifying full closure within 120 seconds in Mode 4 when tested pursuant to Specification 4.0.5. The provisions of Specification 4.0.4 are not applicable for entry into Mode 3.

Docket No. 50-423  
B13343

Attachment 2

Millstone Nuclear Power Station, Unit No. 3

Revised Three-Loop  
Radial Peaking Factor Limit Report

October 1989

WESTINGHOUSE PROPRIETARY CLASS 3

ATTACHMENT 1

Millstone Unit 3, Cycle 3  
Radial Peaking Factor Limit Reports  
for Four Loop and Three Loop Operation



# WESTINGHOUSE PROPRIETARY CLASS 3

## Radial Peaking Factor Limit Report Four Loop Operation

This Radial Peaking Factor Limit Report is provided in accordance with Paragraph 6.9.1.6 of the Millstone Unit 3 Nuclear Plant Technical Specifications.

The four loop operation  $F_{xy}$  limits for RATED THERMAL POWER within specific core planes for Cycle 3 shall be:

1.  $F_{xy}^{RTP}$  less than or equal to 1.79 for all core planes containing Bank "D" control rods, and
2.  $F_{xy}^{RTP}$  less than or equal to 1.67 for all unrodded core planes.

These  $F_{xy}(z)$  limits were used to confirm that the heat flux hot channel factor  $F_Q(z)$  will be limited to the Technical Specification values of:

$$F_Q(z) \leq \left[ \frac{2.32}{P} \right] [K(z)] \text{ for } P > 0.5 \text{ and,}$$

$$F_Q(z) \leq [4.64] [K(z)] \text{ for } P \leq 0.5$$

assuming that most limiting axial power distributions expected to result from the insertion and removal of Control Banks B, C and D during operation, including the accompanying variations in the axial xenon and power distributions as described in the "Power Distribution Control and Load Following Procedures", WCAP-8403, September, 1974. Therefore, these  $F_{xy}$  limits provide assurance that the initial conditions assumed in the LOCA analysis are met, along with the ECCS acceptance criteria of 10CFR50.46.

See Figure 1 for a plot of  $[F_Q^T \cdot P_{Rel}]$  versus Axial Core Height.




FIGURE 1  
 MAXIMUM  $F_Q^T \cdot P_{REL}$  VERSUS AXIAL CORE HEIGHT  
 DURING NORMAL CORE 4 LOOP OPERATION

WESTINGHOUSE PROPRIETARY CLASS 3

Radial Peaking Factor Limit Report  
Three Loop Operation

This Radial Peaking Factor Limit Report is provided in accordance with Paragraph 6.9.1.6 of the Millstone Unit 3 Nuclear Plant Technical Specifications.

The three loop operation  $F_{xy}$  limits for 65% of RATED THERMAL POWER within specific core planes for Cycle 3 shall be:

1.  $F_{xy}^{0.65 \text{ RTP}}$  less than or equal to 1.64 for all core planes containing Bank "D" control rods, and
2.  $F_{xy}^{0.65 \text{ RTP}}$  less than or equal to 1.53 for all unrodded core planes.
3. In the relationship for  $F_{xy}^L$  the multiplier  $M_{Fxy}$  is equal to 0.312.

These  $F_{xy}(z)$  limits were used to confirm that the heat flux hot channel factor  $F_Q(z)$  will be limited to the Technical Specification values of:

$$F_Q(z) \leq \left[ \frac{1.69}{P} \right] [K(z)] \text{ for } 0.65 \geq P > 0.325 \text{ and,}$$

$$F_Q(z) \leq [5.20] [K(z)] \text{ for } P \leq 0.325$$

assuming that most limiting axial power distributions expected to result from the insertion and removal of Control Banks B, C and D during operation, including the accompanying variations in the axial xenon and power distributions as described in the "Power Distribution Control and Load Following Procedures", WCAP-8403, September, 1974. Therefore, these  $F_{xy}$  limits provide assurance that the initial conditions assumed in the LOCA analysis are met, along with the ECCS acceptance criteria of 10CFR50.46.

See Figure 2 for a plot of  $[F_Q^T \cdot P_{Rel}]$  versus Axial Core Height.






FIGURE 2

MAXIMUM  $F_Q^T \cdot P_{REL}$  VERSUS AXIAL CORE HEIGHT  
 DURING NORMAL CORE 3 LOOP OPERATION

WESTINGHOUSE PROPRIETARY CLASS 3

ATTACHMENT 2

Suggested Revision to  
Technical Specification 4.2.2.2.2.e  
and Revised Three Loop Radial Peaking  
Factor Limit Report



POWER DISTRIBUTION LIMITS

SURVEILLANCE REQUIREMENTS

4.2.2.2.1 The provisions of Specification 4.0.4 are not applicable.

4.2.2.2.2  $F_{xy}$  shall be evaluated to determine if  $F_Q(Z)$  is within its limit by:

- a. Using the movable incore detectors to obtain a power distribution map at any THERMAL POWER greater than 5% of RATED THERMAL POWER,
- b. Increasing the measured  $F_{xy}$  component of the power distribution map by 3% to account for manufacturing tolerances and further increasing the value by 5% to account for measurement uncertainties,
- c. Comparing the  $F_{xy}$  computed ( $F_{xy}^C$ ) obtained in Specification 4.2.2.2.2b, above to:
  - 1) The  $F_{xy}$  limits for 65% of RATED THERMAL POWER ( $F_{xy}^{0.65 RTP}$ ) for the appropriate measured core planes given in Specification 4.2.2.2.2a, and f., below, and

2) The relationship:

$$F_{xy}^L = F_{xy}^{0.65 RTP} [1 + M_{F_{xy}}^{0.65} (Z - P)],$$

Where  $F_{xy}^L$  is the limit for fractional THERMAL POWER operation expressed as a function of  $F_{xy}^{0.65 RTP}$ ,  $M_{F_{xy}}$  is the  $F_{xy}$  multiplier, and P is the fraction of RATED THERMAL POWER at which  $F_{xy}$  was measured.

d. Remeasuring  $F_{xy}$  according to the following schedule:

- 1) When  $F_{xy}^C$  is greater than the  $F_{xy}^{0.65 RTP}$  limit for the appropriate measured core plane but less than the  $F_{xy}^L$  relationship, additional power distribution maps shall be taken and  $F_{xy}^C$  compared to  $F_{xy}^{0.65 RTP}$  and  $F_{xy}^L$  either:
  - a) Within 24 hours after exceeding by 20% of RATED THERMAL POWER or greater, the THERMAL POWER at which  $F_{xy}^C$  was last determined, or
  - b) At least once per 31 Effective Full Power Days (EFPD), whichever occurs first.

WESTINGHOUSE PROPRIETARY CLASS 3

Radial Peaking Factor Limit Report  
Three Loop Operation

This Radial Peaking Factor Limit Report is provided in accordance with Paragraph 6.9.1.6 of the Millstone Unit 3 Nuclear Plant Technical Specifications.

The three loop operation  $F_{xy}$  limits for 65% of RATED THERMAL POWER within specific core planes for Cycle 3 shall be:

1.  $F_{xy}^{0.65 \text{ RTP}}$  less than or equal to 1.81 for all core planes containing Bank "D" control rods, and
2.  $F_{xy}^{0.65 \text{ RTP}}$  less than or equal to 1.69 for all unrodded core planes.
3. In the relationship for  $F_{xy}^L$  the multiplier  $M_{Fxy}$  is equal to 0.281.

These  $F_{xy}(z)$  limits were used to confirm that the heat flux hot channel factor  $F_Q(z)$  will be limited to the Technical Specification values of:

$$F_Q(z) \leq \left[ \frac{1.69}{P} \right] [K(z)] \text{ for } 0.65 \geq P > 0.325 \text{ and,}$$

$$F_Q(z) \leq [5.20] [K(z)] \text{ for } P \leq 0.325$$

assuming that most limiting axial power distributions expected to result from the insertion and removal of Control Banks B, C and D during operation, including the accompanying variations in the axial xenon and power distributions as described in the "Power Distribution Control and Load Following Procedures", WCAP-8403, September, 1974. Therefore, these  $F_{xy}$  limits provide assurance that the initial conditions assumed in the LOCA analysis are met, along with the ECCS acceptance criteria of 10CFR50.46.

See Figure 2 for a plot of  $[F_Q^T \cdot P_{Rel}]$  versus Axial Core Height.

Docket No. 50-423  
B13343

Attachment 3

Millstone Nuclear Power Station, Unit No. 3

Examples of  $F_{xy}^L$  Using the  
Current and Proposed Relationships

October 1989



Millstone Nuclear Power Station, Unit No. 3  
 Examples of  $F_{xy}^L$  Using the  
Current and Proposed Relationships

Current	Proposed
$F_{xy}^L = 1.53 [1 + .312 (1 - P)]$ Unrodded  $P = .65$ $F_{xy}^L = 1.69$  $P = .5$ $F_{xy}^L = 1.76$	$F_{xy}^L = 1.69 [1 + .281 (.65 - P)]$ Unrodded  $F_{xy}^L = 1.69$  $F_{xy}^L = 1.76$
$F_{xy}^L = 1.64 [1 + .312 (1 - P)]$ Rodded  $P = .65$ $F_{xy}^L = 1.81$  $P = .5$ $F_{xy}^L = 1.89$	$F_{xy}^L = 1.81 [1 + .281 (.65 - P)]$ Rodded  $F_{xy}^L = 1.81$  $F_{xy}^L = 1.89$
Additional surveillance required when $F_{xy}^C$ is between 1.53/1.64 and the limit.	Additional surveillance required when $F_{xy}^C$ is between 1.69/1.81 and the limit.