Alabama Fower Company
ATTN: Mr. W. G. Hairston, III
Senior Vice President
Nuclear Operations
40 Inverness Center Parkway
P. O. Box 1295
Birmingham, AL 35201

Gentlemen:

SUBJECT: DOCKET NOS. 50-348 AND 50-364, CONFIRMATORY MEASURFMENT RESULTS, SUPPLEMENT TO NRC INSPECTION REPORT NO. 89-06

As part of the NRC Confirmatory Measurements Program, spiked liquid samples were sent on June 13, 1989, to your Farley facility for selected radiochemical analyses. We are in receipt of your analytical results transmitted to us by your letter dated August 23, 1989. The following comparison of your results to the known values are presented in Enclosure 1 for your information. The acceptance criteria for the comparisons are listed in Enclosure 2.

In our review of these data all comparative results were in agreement. These data should be reviewed in detail by cognizant staff members for any significant trends in the data among successive years in which samples have been analyzed by your facility.

These results and any results from previous years pertaining to these analyses will be discussed at future NGC inspections.

Sincerely,

ORIGINAL SIGNED BY THOMAS R. DECKER

Douglas : Collins, Chief Emergency Preparedness and Radiological Protection Branch Division of Radiation Safety and Safeguards

Enclosures:

 Confirmatory Measurement Comparisons

 Criteria for Comparing Analytical Measurements

cc w/encls: (See page 2)

TECO

cc w/encls:
B. L. Moore
Manager, Licensing
Alabama Power Company
P. O. Box 1295
Birmingham, AL 35201

R. P. McDonald Executive Vice President Alabama Power Company P. O. Box 1295 Birmingham, AL 35201

J. D. Woodard Vice President Nuclear Farley Project Alabama Power Company P. O. Box 1295 Birmingham AL 35201

D. N. Morey General Manager Farley Nuclear Plant Drawer 470 Ashford, AL 36312

Louis B. Long, General Manager Southern Company Services, Inc. P. O. Box 2625 Birmingham, AL 35202

Claude Earl Fox, M.D. State Health Officer State Department of Public Health State Office Building Montgomery, AL 36130

Chairman Houston County Commission Dothan, AL 36301

State of Alabama

bcc w/encls: E. Reeves, Project Manager, NRR Document Control Desk

bcc w/encls: (Continued on page 3)

NRC Resident Inspector U.S. Nuclear Regulatory Commission Route 2, Box 24 Columbia, AL 36319

RII: DRSS CAH Chughey 10/3/89 RII:DRSS TDecker 10/5/89

FCantrell 10/6/89

ENCLOSURE 1

CONFIRMATORY MEASUREMENT COMPARISONS OF H-3, FE-55, SR-89 AND SR-90 ANALYSES FOR FARLEY NUCLEAR PLANT ON JUNE 13, 1989

Isotope	NRC (uCi/ml)	Licensee (uCi/ml)	Resolution	Ratio (Licensee/NRC)	Comparison
H-3	3.52±0.11 E-5	3.65 E-5	32	1.04	Agreement
Fe-55	3.80±0.11 E-5	3.7368 E-5	35		Agreement
Sr-89	1.50±0.05 E-4	1.299 E-4	30	0.87	Agreement
Sr-90	8.14±0.33 E-6	6.732 E-6	25	0.83	Agreement

ENCLOSURE 2

CRITERIA FOR COMPARISONS OF ANALYTICAL MEASUREMENTS

This enclosure provides criteria for the comparison of results of analytical radioa livity measurements. These criteria are based on empirical relationships which combine prior experience in comparing radioactivity aralyses, the measurement of the statistically random process of radioactive emission, and the accuracy needs of this program.

In these criteria, the "Comparison Ratio Limits" denoting agreement or disagreement between licensee and NRC results are variable. This variability is a function of the ratio of the NRC's analytical value relative to its associated statistical and analytical uncertainty, referred to in this program as "Resolution".

For comparison purposes, a ratio between the licensee's analytical value and the NRC's analytical value is computed for each radionuclide present in a given sample. The computed ratios are then evaluated for agreement or disagreement based on "Resolution." The corresponding values for "Resolution" and the "Comparison Ratio Limits" are listed in the Table below. Ratio values which are either above or below the "Comparison Ratio Limits" are considered to be in disagreement, while ratio values within or encompassed by the "Comparison Ratio Limits" are considered to be in agreement.

TABLE

NRC Confirmatory Measurements Acceptance Criteria Resolution vs. Comparison Ratio Limits

Resolution	Comparison Ratio Limits for Agreement		
<4	0.4 - 2.5		
4 - 7	0.5 - 2.0		
8 - 15	0.6 - 1.66		
16 - 50	0.75 ~ 1.33		
51 - 200	0.80 - 1.25		
>200	0.85 - 1.18		

¹Comparison Ratio = Licensee Value NRC Reference Value

²Resolution = NRC Reference Value Associated Uncertainty