

CONTAINMENT SYSTEMS

SURVEILLANCE REQUIREMENTS (Continued)

- f. Type B tests for penetrations employing a continuous leakage monitoring system shall be conducted at P_a (60 psig) at intervals no greater than once per 3 years.
- g. All test leakage rates shall be calculated using observed data converted to absolute values. Error analyses shall be performed to determine the inaccuracy of the measured leakage rates due to maximum measurement accuracy and instrument repeatability; the measured leakage rates shall be adjusted to include the measurement error.
- h. The provisions of Specification 4.0.2 are not applicable. |

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the Matter of)
)
PORTLAND GENERAL ELECTRIC COMPANY,) Docket 50-344
THE CITY OF EUGENE, OREGON, AND) Operating License NPF-1
PACIFIC POWER & LIGHT COMPANY)
)
(TROJAN NUCLEAR PLANT))

CERTIFICATE OF SERVICE

I hereby certify that copies of License Change Application 172, Revision 1, to the Operating License for Trojan Nuclear Plant, dated October 25, 1989, have been served on the following by hand delivery or by deposit in the United States mail, first class, this 25th day of October 1989:

State of Oregon
Department of Energy
625 Marion St NE
Salem OR 97310

Mr. Michael J. Sykes
Chairman of County Commissioners
Columbia County Courthouse
St. Helens OR 97051

S. A. Bauer

S. A. Bauer, Manager
Nuclear Regulation Branch
Nuclear Safety & Regulation

Subscribed and sworn to before me this 25th day of October 1989.

Carole A. Hodgson
Notary Public of Oregon

My Commission Expires:

August 9, 1991

