



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

OMAHA PUBLIC POWER DISTRICT

DOCKET NO. 50-285

FORT CALHOUN STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 123  
License No. DPR-40

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by the Omaha Public Power District (the licensee) dated September 8, 1989, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, as amended, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this license amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, Facility Operating License No. DPR-40 is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 3.B. of Facility Operating License No. DPR-40 is hereby amended to read as follows:

B. Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 123, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. The license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

*for*   
Frederick J. Heck, Director  
Project Directorate IV  
Division of Reactor Projects - III,  
IV, V and Special Projects  
Office of Nuclear Reactor Regulation

Attachment:  
Charges to the Technical  
Specifications

Date of Issuance: 123

ATTACHMENT TO LICENSE AMENDMENT NO. 123

FACILITY OPERATING LICENSE NO. DPR-40

DOCKET NO. 50-285

Revise Appendix "A" Technical Specifications as indicated below. The revised page is identified by amendment number and contains a vertical line indicating the area of change.

Remove Page

3-15

Insert Page

3-15



TABLE 3-3 (Continued)

MINIMUM FREQUENCIES FOR CHECKS, CALIBRATIONS AND TESTING  
OF MISCELLANEOUS INSTRUMENTATION AND CONTROLS

| <u>Channel Description</u>                               | <u>Surveillance Function</u> | <u>Frequency</u> | <u>Surveillance Method</u>   |
|--|------------------------------|------------------|--|
| 8. Dropped CEA Indication                                | a. Test                      | R                | a. Insert a negative rate of change power signal to all four Power Range Safety Channels to test alarm.                            |
|  | b. Test                      | P                | b. Insert CEA's below lower electrical limit to test dropped CEA alarm.  |
| 9. Calorimetric Instrumentation                          | a. Calibrate                 | R                | a. Apply known d/p to feed-water flow sensors.   |
| 10. Control Room Ventilation                             | a. Test                      | F                | a. Check damper operation for DBA mode.  |
|  | b. Test                      | R                | b. Check control room for positive pressure.   |
| 11. Containment Humidity Detector                        | a. Test                      | R                | a. Place sensor in a known high humidity atmosphere.   |
| 12. Interlocks-Isolation Valves on Shutdown Cooling Line | a. Test                      | R                | a. Known pressure of 265 psia applied to pressure transmitter and pressure switch and operability of redundant interlock verified. |
| 13. Control Room Thermometer                             | a. Test                      | R                | a. Compare reading with calibrated thermometer. If not within $\pm 2^{\circ}\text{F}$ , replace.                                   |