Docket No. 030-03367

46-00990-01

Veterans Administration Medical Center 1660 South Columbian Way Seattle, WA 98108

Attention: Mr. J. T. Krajeck Director

Thank you for your letter dated October 24, 1989 informing us of the steps you have taken to correct the items which we brought to your attention in our etter dated October 11, 1989.

With regards to your corrective action for item B, i.e. ash residue analysis, we make the following comments:

- Establish and document your procedure to ensure that a truly representative sample of ash is obtained for analyses.
- 2. Establish and document your procedure for the analyses of radionuclides in ash residue. Note that the analyses of sulfur 35 in ash residues requires special considerations because of the low energy beta emission which has a maximum energy of 0.165 Mev. The procedure must include precautions which must be taken to eliminate the self absorption of the ash residue particles for the low energy beta of sulfur-35, if present.

Your corrective actions will be verified during our next inspection.

Your cooperation with us is appreciated.

Sincerely,

Nuclear Materials Safety and

Safeguards Branch

bcc w/copy of letter dated 10/11/89: docket file

State of Washington

A. Johnson

G. Cook

B. Faulkenberry

J. Martin

J. Zollicoffer

M. Smith


TEOS

8911130368 891106 REG5 LIC30 46-00990-01 PNU REGION V JFPang SP 20/3/89 RDThomas 76/3/89

RJPate 2076/89

REQUEST COPY | REQUEST COPY | REQUEST CORY YES / NO | YES / NO | YES / NO |

SEND TO PDR YES / NO





89 OCT 30 AID: Intheply Refer To:

663/11R

U.S. Nuclear Regulatory Commission ATTN: Document Control Desk Washington, D.C. 20555

SUBJ: Reply to a Notice of Violation Docket No. 030-03367 License No. 46-00990-01

This correspondence refers to the safety inspection conducted on August 10 and 11, 1989 and the subsequent "Notice of Violation" letter of October 11, 1989. This response will address each of the six violations as described in that letter.

A. Violation: Security of licensed material in the Nuclear Medicine radiopharmacy.

Corrective Action: The window between the injection room and the radiopharmacy has been modified to reduce the size of the opening to 20 X 20 cm. Also, a convex mirror has been installed in the main Nuclear Medicine Service hallway to facilitate the observation of personnel in the radiopharmacy area.

B. Violation: Appropriate surveys had not been made to determine the concentrations of licensed material in the ash residue prior to disposal.

Reason for Violation: The survey procedure used by the Radiation Safety Officer did not include the use of an appropriate survey instrument, nor were the results recorded in microcuries per gram.

Corrective Action: Ash residue analysis is currently conducted according to the following procedure; Analysis of ash residue is accomplished the morning after radioactive animal carcasses are incinerated. Three one gram samples of ash are obtained from varying levels within a one cubic foot sampling taken from the incinerator prior to ash disposal. The three samples are analyzed using a Ludlum 261 single channel analyzer with a well counter. Ash residues containing only 35 are analyzed using a Ludlum 2200 single channel analyzer and a Nuclear Associates STB-3 "drawer" style counting probe. Counting efficiency is determined using appropriate standards and the results are recorded in microcuries program. This procedure was instituted on August 16, 1989.

SUBJ: Reply to a Notice of Violation Docket No. 030-03367 License No. 46-00990-01

C.1. Violation: Annual refresher raining had not been provided to all authorized users.

Reason for Violation: Absence of a good mechanism for determining which employees had or had not received annual radiation safety refresher training.

Corrective Action: A master list (database) of all General Medical Research employees is now contained in the RSO computer. The fields within this database contain the employee name, social security number, Principal Investigator, laboratory location, most recent training date, University of Washington Radiation Safety Course attendance verification, and iodination training verification. The database is linked to the computer tickler file program so that automatic notification is achieved two weeks before annual refresher training is due. This database is currently in use and will assist the RSO in determining compliance with initial and annual refresher training requirements.

Twenty-nine members of the Building Management staff were provided annual radiation safety refresher training on August 31, 1989. Ancillary worker refresher training records are also linked to the computer tickler file program.

C.2. Violation: Radioactive contaminated waste was found in two of the bags of nonradioactive trash collected from the nuclear medicine laboratory area.

Reason for Violation: Since the trash surveyed by the Nuclear Regulatory Commission inspector had been removed from all areas of the nuclear medicine laboratory, including the patient rest room, it was not possible to ascertain whether the sources of the activity detected within the two bags was patient excreta as we suspect, or material not detected during the daily contamination survey procedure. Neither the NRC inspector or the RSO attempted to open the bags of waste to further investigate the findings because of the potential biohazards involved with the waste. Nonetheless, it was assumed that the trash was inadequately surveyed before being discarded.

SUBJ: Reply to a Notice of Violation Docket No. 030-03367 License No. 46-00990-01

Corrective Action: Daily contamination surveys will be modified to include those trash containers which have a high probability of containing radioactively contaminated articles. Those articles which are detected as being radioactive will be sequestered for decay according to established procedures. This corrective action will be instituted immediately.

Violation: Records of wipe surveys with negative results conducted in laboratories using tritium had not been maintained.

Reason for Violation: The RSO felt that since the survey results were negative, they did not need to be maintained as part of the record.

Corrective Action: All negative laboratory survey results, tritium or otherwise, have been saved and are integrated as part of the survey records beginning with March, 1989.

C.4. Violation: Thyroid bioassays had not been conducted during the fourth quarter of 1988 as required.

Reason for Violation: The RSO was on vacation during December, 1988, and the individual providing coverage during this time was unaware of the exact deadline for thyroid bioassays.

Corrective Action: The periodicity of this function is currently contained in the tickler file program of the RSO computer. This program actively notifies the RSO two weeks before bioassays are due.

If you require further information regarding these matters, please contact Mr. Michael Simmons, RSO, at FTS# 396-1789.

Sincerely,

T. Krayeck

cc: Regional Administration Region V

Docket Nos. 50-213, 50-245, 50-336 and 50-423

Mr. Edward J. Mroczka
Senior Vice President
Nuclear Engineering and Operations
Connecticut Yankee Atomic Power Company
Northeast Nuclear Energy Company
Post Office Box 270
Hartford, Connecticut 06141-0270

Dear Mr. Mroczka:

SUBJECT: RECEIPT OF 60-DAY RESPONSE TO GENERIC LETTER 88-20.

INDIVIDUAL PLANT EXAMINATIONS (IPE) (TAC NO. 74417,

74432, 74433 and 74434)

Re: Haddam Neck and Millstone Units 1, 2 and 3

We have received your letters dated July 27 and October 1, 1989, in response to the 60-day reporting requirements of Generic Letter 88-20. The staff will review your proposed IPE plan for conformance to the requirements of the generic letter and will review all of the licensees' proposed schedules together for reasonableness and to determine the impact on licensee and staff resources. If your proposed plan and/or schedule are not acceptable, the IPE review team and I will contact you as soon as possible to explain the staff's position. Otherwise, the staff will document the acceptability of your plan and schedule in a letter by December 1, 1989.

Should you have any questions concerning the generic letter, please contact Michael L. Boyle, NRR at (301) 492-1308 or John H. Flack, RES at (301) 492-3979.

Sincerely,

151

John F. Stolz, Director Project Directorate I-4 Division of Reactor Projects - I/II Office of Nuclear Reactor Regulation

cc: See next page

Dro

Distribution
Docket File
B. Boger (14A2)

NRC & Local PDRs S. Norris

ACRS (10)

A. Wang

Plant File OGC

S. Varga (14E4)

M. Boyle J. Flack (NLS324)

NAME :SNorris :AWang: (TWO :DJaffe) :MBoyle :GVissing :JStor : DATE :11,' 7/89 :11/7/89 :11/7/89 :11/7/89 :11/7/89 :					:PM:PDI-4	. NN 11		
DATE :11,7/89 :11/7/89 :11/7/89 :11/6/89 :11/7/89 :11/7/89 :	NAME	:SNorris	:AWang: BRO	:DJaffe	:MBoy le	:Gvissing 6	JStot	
	DATE	:11,' 7/89	:11/7/89	:11/7/89	:11/6/89	:11/7/89	:11/7/89 :	

Document Name: TPE 60 DAY LETTER I

Mr. Edward J. Mroczka Northeast Nuclear Energy Company

cc:

Gerald Garfield, Esquire
Day, Berry and Howard
Counselors at Law
City Place
Hartford, Connecticut 06103-3499

W. D. Romberg, Vice President Nuclear Operations Northeast Utilities Service Company Post Office Box 270 Hartford, Connecticut 06141-0270

Kevin McCarthy, Director Radiation Control Unit Department of Environmental Protection State Office Building Hartford, Connecticut 06106

Bradford S. Chase, Under Secretary Energy Division Office of Policy and Management 80 Washington Street Hartford, Connecticut 06106

S. E. Scace, Station Superintendent Millstone Nuclear Power Station Northeast Nuclear Energy Company Post Office Box 123 Waterford, Connecticut 06385

C. H. Clement, Unit Superintendent Millstone Unit No. 3 Northeast Nuclear Energy Company Post Office Box 128 Waterford, Connecticut 06385

Ms. Jane Spector Federal Energy Regulatory Commission 825 N. Capitol Street, N.E. Room 8608C Washington, D.C. 20426

Burlington Electric Department c/o Robert E. Fletcher, Esq. 271 South Union Street Burlington, Vermont 05402 Haddam Neck & Millstone Nuclear Power Station Unit Nos. 1, 2 & 3

R. M. Kacich, Manager Generation Facilities Licensing Northeast Utilities Service Company Post Office Box 270 Hartford, Connecticut 06141-0270

D. O. Nordquist
Manager of Quality Assurance
Northeast Nuclear Energy Company
Post Office Box 270
Hartford, Connecticut 06141-0270

Regional Administrator Region I U. S. Nuclear Regulatory Commission 475 Allendale Road King of Prussia, Pennsylvania 19406

First Selectmen
Town of Waterford
Hall of Records
200 Boston Post Road
Waterford, Connecticut 06385

W. J. Raymond, Resident Inspector Millstone Nuclear Power Station c/o U. S. Nuclear Regulatory Commission Post Office Box 811 Niantic, Connecticut 06357

M. R. Scully, Executive Director Connecticut Municipal Electric Energy Cooperative 30 Stott Avenue Norwich, Connecticut 06360

Michael L. Jones, Manager
Project Management Department
Massachusetts Municipal Wholesale
Electric Company
Post Office Box 426
Ludlow, Massachusetts 01056

Mr. Edward J. Mroczka Northeast Nuclear Energy Company

J. P. Stetz, Unit Superintendent Millstone Unit No. 1 Northeast Nuclear Energy Company Post Office Box 128 Waterford, Connecticut 06385

Charles Brinkman, Manager Washington Nuclear Operations C-E Power Systems Combustion Engineering, Inc. 12300 Twinbook Pkwy Suite 330 Rockville, Maryland 20852

D. B. Miller, Station Superintendent Haddam Neck Plant Connecticut Yankee Atomic Power Company RFD 1, Post Office Box 127E East Hampton, Connecticut 06424

G. H. Bouchard, Unit Superintendent Haddam Neck Plant RFD #1 Post Office Eox 127E East Hampton, Connecticut 06424 Haddam Neck & Millstone Nuclear Power Station Unit Nos. 1, 2 & 3

J. S. Keenan, Unit Superintendent Milistone Unit No. 2 Northeast Nuclear Energy Company Post Office Box 128 Waterford, Connecticut 06385

Board of Selectmen Town Hall Haddam, Connecticut 06103

J. T. Shedlosky, Resident Inspector Haddam Neck Plant c/o U. S. Nuclear Regulatory Commission Post Office Box 116 East Haddam Post Office East Haddam, Connecticut 06423