



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

DUQUESNE LIGHT COMPANY

OHIO EDISON COMPANY

PENNSYLVANIA POWER COMPANY

DOCKET NO. 50-334

BEAVER VALLEY POWER STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 146
License No. DPR-66

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Duquesne Light Company, et al. (the licensee) dated September 22, 1989 complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

8911140042 891102
PDR ADOCK 05000334
P PIC

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-66 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 146, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective on issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



John F. Stolz, Director
Project Directorate I-4
Division of Reactor Projects - I/11
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: November 2, 1989

ATTACHMENT TO LICENSE AMENDMENT NO. 146

FACILITY OPERATING LICENSE NO. DPR-66

DOCKET NO. 50-334

Replace the following page of Appendix A, (Technical Specifications) with the enclosed page as indicated. The revised page is identified by amendment number and contains a vertical line indicating the area of change.

Remove

3/4 6-19j

Insert

3/4 6-19j

TABLE 3.6-1
CONTAINMENT PENETRATIONS

Beaver Valley Unit 1	PENT.	IDENTIFICATION/DESCRIPTION	INSIDE VALVE	MAXIMUM STROKE TIME* (SEC)	OUTSIDE VALVE	MAXIMUM STROKE TIME* (SEC)
	NO. -AREA					
1	110-1-C	FRZR Dead Weight Calibrator PT-RC-455A	Closed System	N/A	(1) IRC-277 (1) IRC-278	N/A N/A
	110-2-C	Spare				
	110-3-C	Spare				
	110-4-C	Spare				
3/4 6-19j	111-C	Spare			(7) Flange	N/A
	112-C	Spare			(7) Flange	N/A
	113-1-A	BIT to Cold Legs	(2) ISI-94	N/A	(2) MOV-LSI-867C (2) MOV-LSI-867D	15 15

Primary Containment Airlock PH-P-1

Equalization Valve	(8) (7) SOV-1VS-2	N/A	
Equalization Valve	(7) -169	N/A	
Equalization Valve	(7) 1VS-170	N/A	
Equalization Valve	(8) (7) SOV-1VS-4	N/A	
Equalization Valve			(8) (7) SOV-1VS-5
Equalization Valve			(7) 1VS-167
Equalization Valve			(7) 1VS-163
Equalization Valve			(8) (7) SOV-1VS-6