Docket No. 50-245

Mr. Edward J. Mroczka Senior Vice President Nuclear Engineering and Operations Connecticut Yankee Atomic Power Company Northeast Nuclear Energy Company P. O. Box 270 Hartford, Connecticut 06141-0270

Dear Mr. Mroczka:

SUBJECT: ISSUANCE OF AMENDMENT (TAC NO. 74175)

The Commission has issued the enclosed Amendment No. 36to Facility Operating License No. DPR-21 for Millstone Nuclear Power Station, Unit No. 1, in response to your application dated July 31, 1989.

The amendment revises the Technical Specifications to correctly list the distribution voltage for the primary side of the Emergency Station Services Transformer as 23KV.

A copy of the related Safety Evaluation is also enclosed. The notice of issuance will be included in the Commission's bi-weekly Federal Register notice.

Sincerely.

151

Michael L. Boyle, Project Manager Project Directorate I-4 Division of Reactor Projects - I/II Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 36 to DPR-21

Safety Evaluation

cc w/enclosures: See next page

[AMEND 74175]

LA:PDI-4 SNorris 10/23/89 PM: PDI -4 MUD MBoy le: dr 10/24/89

PD:RDI-4 JStorz. 10/4/189 06CoB arth 10/21/89



NUCLEAR HEGULATORY COMMISSION WASHINGTON, D. C. 20666

November 1, 1989

Docket No. 50-245

Mr. Edward J. Mrocika
Senior Vice President
Nuclear Engineering and Operations
Connecticut Yankee Atomic Power Company
Northeast Nuclear Energy Company
P. O. Box 270
Hartford, Connecticut 06141-0270

Dear Mr. Mroczka:

SUBJECY: ISSUANCE OF AMENDMENT (TAC NO. 74175)

The Commission has issued the enclosed Amendment No. 36 to Facility Operating License No. DPR-21 for Millstone Nuclear Power Station, Unit No. 1, in response to your application dated July 31, 1989.

The amendment revises the Technical Specifications to correctly list the distribution voltage for the primary side of the Emergency Station Services Transformer as 23KV.

A copy of the related Safety Evaluation is also enclosed. The notice of issuance will be included in the Commission's bi-weekly Federal Register notice.

Sincerely,

Michael L. Boyle, Project Manager Project Directurate 1-4

Division of Reactor Projects - 1/11 Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 36 to DPR-21

2. Safety Evaluation

see next page

Mr. Edward J. Mroczka Northeast Nuclear Energy Company

cc:

Gerald Garfield, Esquire Day, Berry and Howard Counselors at Law City Place Hartford, Connecticut 06103-3499

W. D. Romberg, Vice President Nuclear Operations Northeast Utilities Service Company Post Office Box 270 Hartford, Connecticut 06141-0270

Kevin McCarthy, Director Radiation Control Unit Department of Environmental Protection State Office Building Hartford, Connecticut 06106

Bradford S. Chase, Under Secretary Energy Division Office of Policy and Management 80 Washington Street Hartford, Connecticut 06106

S. E. Scace, Station Superintendent Milistone Nuclear Power Station Northeast Nuclear Energy Company Post Office Box 128 Waterford, Connecticut 06385

J. P. Stetz, Unit Superintendent Millstone Unit No. 1 Northeast Nuclear Energy Company Post Office Box 128 Waterford, Connecticut 06385

Mr. Edward J. Mroczka Senior Vice President Nuclear Engineering and Operations Connecticut Yankee Atomic Power Company Northeast Nuclear Energy Company P. O. Box 270 Hartford, Connecticut 06141-0270 Millstone Nuclear Fower Station Unit No. 1

R. M. Kacich, Manager Generation Facilities Licensing Northeast Utilities Service Company Post Office Box 270 Hartford, Connecticut 06141-0270

D. O. Nordquist
Manager of Quality Assurance
Northeast Nuclear Energy Company
Post Office Box 270
Hartford, Connecticut 06141-0270

Regional Administrator Region I U. S. Nuclear Regulatory Commission 475 Allendale Road King of Prussia, Pennsylvania 19406

First Selectmen Town of Waterford Hall of Records 200 Boston Post Road Waterford, Connecticut 06385

W. J. Raymond, Resident Inspector Millstone Nuclear Power Station c/o U. S. Nuclear Regulatory Commission Post Office Box 811 Niantic, Connecticut 06357