




UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

TAC 49335

March 14, 1983


Docket No. 50-339

MEMORANDUM FOR: H. Denton
E. Case
J. Carter
D. Eisenhut
K. Purple
DL Assistant Directors
OR Branch Chiefs
R. Vollmer
R. Mattson
H. Thompson
J. Sniezek
C. J. Heltemes
T. Speis
T. Ippolito

THRU: Steven A. Varga, Chief, ORB#1, DL 
FROM: P. S. Tam, Project Manager, ORB#1, DL
SUBJECT: DAILY HIGHLIGHT

Beaver Valley Unit 1 - Exemption to Appendix R

The staff has granted an Exemption to Subsection III.G and III.L of Appendix R (Fire Protection) on this date. This Exemption covers seven fire areas: control room, primary auxiliary building, containment, pipe tunnel, cable tunnel, HVAC ductwork for the charging pump cubicles, emergency switchgear room. The Exemption also allows the achievement of cold shutdown, in the absence of offsite power and the RHR system, in 127 hours (instead of 72 hours as required by Subsection III.L).



P. S. Tam, Project Manager
Operating Reactors Branch #1, DL

DF01
1/0

8911150263 830314
FDR ADOCK 05000334
F PDC