

MAY 2 1976

Darrell G. Eisenhut, Assistant Director for Operational Technology, DOR
TECHNICAL ASSISTANCE REQUEST NO. ORB-1-241

Your assistance is requested for the following:

PLANT NAME: Oconee Units No. 1, No. 2 and No. 3
DOCKET NOS: 50-269, 50-270 and 50-287
RESPONSIBLE BRANCH: ORB-1
CONTACT: Gary G. Zech (x27433)
TECHNICAL REVIEW BRANCH: Environment 1 Evaluation Branch

DESCRIPTION OF REQUEST: By the enclosed letter dated May 13, 1976, Duke Power Company (DPC), proposed an amendment to Appendix B of the Oconee Technical Specifications which would increase the upper pH limit of water discharged from the Oconee Station site from 8.5 to 9.0.

You are requested to review the licensee's proposal and provide a written response as to its acceptability.

TARGET DATE FOR COMPLETION: July 15, 1976

Original signed by:
Robert A. Purple

Robert A. Purple, Chief
Operating Reactors Branch #1
Division of Operating Reactors

cc: B. K. Grimes

DISTRIBUTION:

- Docket File
- ORB#1 Reading
- Subject File
- RAPurple
- GGZech
- SSheppard
- KGoller
- VStello
- TCarter

| | | | | | |
|-----------|-----------|----------|--|--|--|
| OFFICE → | ORB#1 | ORB#1 | | | |
| x27433 | GZech:tsu | RAPurple | | | |
| SURNAME → | | | | | |
| DATE → | 5/28/76 | 5/28/76 | | | |